

PLAINVIEW WATER DISTRICT  
2003 WATER QUALITY DATA

PARAMETERS (mg/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095 <sup>(1)</sup>		WELL NO. 1-2 N-4096 <sup>(1)</sup>		WELL NO. 2-1 N-7526 <sup>(1)</sup>		WELL NO. 3-1 N-4097	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b>INORGANIC</b>										
ARSENIC	5.0 ug/l	3.0 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
BARIUM	2.0 mg/l	0.2 mg/l	ND	ND	ND	ND	ND	ND		
CADMIUM	5.0 mg/l	5.0 mg/l	ND	ND	ND	ND	ND	ND		
CHROMIUM	0.10 mg/l	0.01 mg/l	ND	ND	ND	ND	ND	ND		
COPPER	[1.3] mg/l	0.02 mg/l	ND	ND	ND	ND	ND	ND		
FLUORIDE	2.2 mg/l	0.1 mg/l	ND	ND	ND	ND	ND	ND		
LEAD	[15.0] mg/l	1.0 mg/l	ND	ND	0.002	0.002	0.001	0.001		
MERCURY	2.0 mg/l	0.2 mg/l	ND	ND	ND	ND	ND	ND		
LANGLIER SATURATION INDEX	None	None	-3.52	-3.52	-5.63	-5.63	-2.56	-2.56		
SELENIUM	50 mg/l	5 mg/l	ND	ND	ND	ND	ND	ND		
SILVER	0.05 mg/l	0.01 mg/l	ND	ND	ND	ND	ND	ND		
SODIUM	**20/270 mg/l	0.2 mg/l	5.2	5.2	6.8	6.8	5.2	5.2		
ZINC	5.0 mg/l	0.02 mg/l	ND	ND	ND	ND	0.04	0.04		
COLOR	15 Units	5 Units	ND	ND	ND	ND	ND	ND		
TURBIDITY	5 Units	1 Unit	ND	ND	ND	ND	ND	ND		
ODOR	3 Units	0 Units	ND	ND	ND	ND	ND	ND		
IRON	0.3 mg/l	0.02 mg/l	0.06	0.06	ND	ND	0.3	0.3		
MANGANESE	0.3 mg/l	0.01 mg/l	ND	ND	ND	ND	0.04	0.04		
AMMONIA	None	0.02 mg/l	ND	ND	ND	ND	ND	ND		
NITRITE	1.0 mg/l	0.1 mg/l	ND	ND	ND	ND	ND	ND		
NITRATE	10.0 mg/l	0.1 mg/l	3.3	3.3	5.1	5.1	4.7	4.7		
CHLORIDE	250 mg/l	2.0 mg/l	4.0	4.0	5.6	5.6	4.9	4.9		
TOTAL HARDNESS	None	1.3 mg/l	22.0	22.0	17.9	17.9	27.4	27.4		
TOTAL ALKALINITY	None	0 mg/l	10.3	10.3	1.2	1.2	28.8	28.8		
pH (BEFORE TREATMENT)	None	None	6.1	6.1	5.1	5.1	6.5	6.5		
TOTAL DISSOLVED SOLIDS	None	5.0 mg/l	66.0	66.0	102.0	102.0	122.0	122.0		
DETERGENTS (MBAS)	None	0.084 mg/l	ND	ND	ND	ND	ND	ND		
SULFATE	250 mg/l	5.0 mg/l	ND	ND	ND	ND	ND	ND		
FREE CYANIDE	200 ug/l	<10.0 ug/l	ND	ND	ND	ND	ND	ND		
ANTIMONY	6.0 ug/l	5.9 ug/l	ND	ND	ND	ND	ND	ND		
BERYLLIUM	4.0 ug/l	3.0 ug/l	ND	ND	ND	ND	ND	ND		
CALCIUM	None	0.2 mg/l	6.9	6.9	4.6	4.6	9.1	9.1		
MAGNESIUM	None	0.2 mg/l	1.1	1.1	1.6	1.6	1.1	1.1		
NICKEL	0.10 mg/l	0.04 mg/l	ND	ND	ND	ND	ND	ND		
THALLIUM	2.0 ug/l	1.9 ug/l	ND	ND	ND	ND	ND	ND		
PERCHLORATE	18 ug/l	4.0 ug/l	1.8	1.8	2.7	2.7	2.3	2.3		

CONT. - CONTAMINANT

ND - NOT DETECTED

\*\* - 20 mg/l IS THE LIMIT FOR PEOPLE ON HIGHLY RESTRICTED SODIUM DIETS AND 270 mg/l FOR THOSE ON MODERATELY RESTRICTED SODIUM DIETS

[ ] - USEPA/NYS DH ACTION LEVEL

WELL NO. 3-1 - OUT OF SERVICE

<sup>(1)</sup> ONE SAMPLE WAS TAKEN FROM WELL

PLAINVIEW WATER DISTRICT  
2003 WATER QUALITY DATA (continued)

PARAMETERS (mg/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077 <sup>(3)</sup>		WELL NO. 4-3 N-6076 <sup>(1)</sup>		WELL NO. 5-1 N-6956 <sup>(1)</sup>	
			MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)
<b>INORGANIC</b>										
ARSENIC	5.0 ug/l	3.0 ug/l	OUT OF SERVICE		ND	ND	ND	ND	ND	ND
BARIUM	2.0 mg/l	0.2 mg/l			ND	ND	ND	ND	ND	ND
CADMIUM	5.0 mg/l	5.0 mg/l			ND	ND	ND	ND	ND	ND
CHROMIUM	0.10 mg/l	0.01 mg/l			ND	ND	ND	ND	ND	ND
COPPER	[1.3] mg/l	0.02 mg/l			0.02/ND	0.01/ND	ND	ND	0.04/ND	0.02/ND
FLUORIDE	2.2 mg/l	0.1 mg/l			ND	ND	ND	ND	ND	ND
LEAD	[15.0] mg/l	1.0 mg/l			0.02/ND	0.01/ND	ND	ND	0.002/ND	0.001/ND
MERCURY	2.0 mg/l	0.2 mg/l			ND	ND	ND	ND	ND	ND
LANGLIER SATURATION INDEX	None	None			-4.92/-2-96	-4.85/-2.96	-5.47	-5.47	-6.34/ND	-1.57/ND
SELENIUM	50 mg/l	5 mg/l			ND	ND	ND	ND	ND	ND
SILVER	0.05 mg/l	0.01 mg/l			ND	ND	ND	ND	ND	ND
SODIUM	**20/270 mg/l	0.2 mg/l			13.8/13.7	13.7/13.7	4.8	4.8	6.4/ND	4.3/ND
ZINC	5.0 mg/l	0.02 mg/l			0.04/ND	0.02ND	ND	ND	ND	ND
COLOR	15 Units	5 Units			ND	ND	ND	ND	ND	ND
TURBIDITY	5 Units	1 Unit			ND	ND	ND	ND	ND	ND
ODOR	3 Units	0 Units			ND	ND	ND	ND	ND	ND
IRON	0.3 mg/l	0.02 mg/l			ND	ND	ND	ND	1.3/ND	1.2/ND
MANGANESE	0.3 mg/l	0.01 mg/l			ND	ND	ND	ND	0.1/ND	0.08/ND
AMMONIA	None	0.02 mg/l			ND	ND	ND	ND	0.5/ND	0.4/ND
NITRITE	1.0 mg/l	0.1 mg/l			ND	ND	ND	ND	ND	ND
NITRATE	10.0 mg/l	0.1 mg/l			10.8 <sup>(4)</sup> /10.8	10.6/10.8	2.5 <sup>(3)</sup>	2.1	3.5/ND	2.0/ND
CHLORIDE	250 mg/l	2.0 mg/l			21.4/20.1	21.2/20.1	3.9	3.9	5.5/ND	4.1/ND
TOTAL HARDNESS	None	1.3 mg/l			41.5/40.8	41.0/40.8	8.2	8.2	25.2/ND	14.5/ND
TOTAL ALKALINITY	None	0 mg/l			3.0/3.4	2.9/3.4	2.4	2.4	17.1/ND	8.6/ND
pH (BEFORE TREATMENT)	None	None			5.2/7.0	5.2/7.0	5.3	5.3	6.2/ND	5.6/ND
TOTAL DISSOLVED SOLIDS	None	5.0 mg/l			158.0/251.0	134.0/251.0	12.0	12.0	40.0/ND	30.5/ND
DETERGENTS (MBAS)	None	0.084 mg/l			ND	ND	ND	ND	ND	ND
SULFATE	250 mg/l	5.0 mg/l			ND	ND	ND	ND	ND	ND
FREE CYANIDE	200 ug/l	<10.0 ug/l			ND	ND	ND	ND	ND	ND
ANTIMONY	6.0 ug/l	5.9 ug/l			ND	ND	ND	ND	ND	ND
BERYLLIUM	4.0 ug/l	3.0 ug/l			ND	ND	ND	ND	ND	ND
CALCIUM	None	0.2 mg/l			10.6/10.4	10.5/10.4	2.1	2.1	7.8/ND	4.4/ND
MAGNESIUM	None	0.2 mg/l			3.7/3.6	3.6/3.6	0.7	0.7	1.4/ND	0.8/ND
NICKEL	0.10 mg/l	0.04 mg/l			ND	ND	ND	ND	ND	ND
THALLIUM	2.0 ug/l	1.9 ug/l			ND	ND	ND	ND	ND	ND
PERCHLORATE	18 ug/l	4.0 ug/l			8.9/ND	7.8/ND	3.6	3.6	2.2/ND	1.1/ND

ND - NOT DETECTED

\*\*\* - EXCEEDS NEW YORK STATE/USEPA LIMITS FOR POTABLE WATER

\*\* - 20 mg/l IS THE LIMIT FOR PEOPLE ON HIGHLY RESTRICTED SODIUM DIETS AND 270 mg/l FOR THOSE ON MODERATELY RESTRICTED SODIUM DIETS

[ ] - USEPA/NYS DH ACTION LEVEL

WELL NO. 3-2 - OUT OF SERVICE

<sup>(1)</sup> ONE SAMPLE WAS TAKEN FROM WELL

<sup>(3)</sup> THREE SAMPLES WERE TAKEN FROM WELL

<sup>(4)</sup> FOUR SAMPLES WERE TAKEN FROM WELL

**PLAINVIEW WATER DISTRICT  
2003 WATER QUALITY DATA (continued)**

PARAMETERS (mg/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421 <sup>(1)</sup>		WELL NO. 5-3 N-7421 <sup>(1)</sup>		WELL NO. 5-4 N-8595 <sup>(1)</sup>		WELL NO. 7-1 <sup>(1)</sup>	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b><u>INORGANIC</u></b>										
ARSENIC	5.0 ug/l	3.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
BARIUM	2.0 mg/l	0.2 mg/l	ND	ND	ND	ND	ND	ND	ND	ND
CADMIUM	5.0 mg/l	5.0 mg/l	ND	ND	ND	ND	ND	ND	ND	ND
CHROMIUM	0.10 mg/l	0.01 mg/l	ND	ND	ND	ND	ND	ND	ND	ND
COPPER	[1.3] mg/l	0.02 mg/l	ND	ND	0.03	0.03	ND	ND	ND	ND
FLUORIDE	2.2 mg/l	0.1 mg/l	ND	ND	ND	ND	ND	ND	ND	ND
LEAD	[15.0] mg/l	1.0 mg/l	0.003/ND	0.003/ND	ND	ND	0.011	0.011	0.002	0.002
MERCURY	2.0 mg/l	0.2 mg/l	ND	ND	ND	ND	ND	ND	ND	ND
LANGLIER SATURATION INDEX	None	None	-6.0/ND	-6.0/ND	-0.325	-3.25	-5.35	-5.35	-2.44	-2.44
SELENIUM	50 mg/l	5 mg/l	ND	ND	ND	ND	ND	ND	ND	ND
SILVER	0.05 mg/l	0.01 mg/l	ND	ND	ND	ND	ND	ND	ND	ND
SODIUM	**20/270 mg/l	0.2 mg/l	8.9/ND	8.9/ND	7.5	7.5	2.6	2.6	6.6	6.6
ZINC	5.0 mg/l	0.02 mg/l	0.02/ND	0.02/ND	ND	ND	ND	ND	ND	ND
COLOR	15 Units	5 Units	ND	ND	ND	ND	ND	ND	ND	ND
TURBIDITY	5 Units	1 Unit	ND	ND	ND	ND	ND	ND	ND	ND
ODOR	3 Units	0 Units	ND	ND	ND	ND	ND	ND	ND	ND
IRON	0.3 mg/l	0.02 mg/l	ND	ND	ND	ND	0.14	0.14	0.13	0.13
MANGANESE	0.3 mg/l	0.01 mg/l	ND	ND	ND	ND	ND	ND	0.02	0.02
AMMONIA	None	0.02 mg/l	ND	ND	ND	ND	ND	ND	ND	ND
NITRITE	1.0 mg/l	0.1 mg/l	ND	ND	ND	ND	ND	ND	ND	ND
NITRATE	10.0 mg/l	0.1 mg/l	5.2/ND	5.2/ND	4.6	4.6	0.50	0.5	4.6 <sup>(2)</sup>	4.2
CHLORIDE	250 mg/l	2.0 mg/l	13.4/ND	13.4/ND	8.9	8.9	3.2	3.2	5.0	5.0
TOTAL HARDNESS	None	1.3 mg/l	20.1/ND	20.1/ND	23.3	23.3	7.1	7.1	40.3	40.3
TOTAL ALKALINITY	None	0 mg/l	ND	ND	7.9	7.9	4.6	4.6	25.2	25.2
pH (BEFORE TREATMENT)	None	None	4.8/ND	4.8/ND	6.5	6.5	5.3 <sup>(2)</sup>	5.2 <sup>(2)</sup>	6.5	6.5
TOTAL DISSOLVED SOLIDS	None	5.0 mg/l	68.0/ND	68.0/ND	62.0	62.0	18.0	18.0	1030 <sup>(2)</sup>	537.5
DETERGENTS (MBAS)	None	0.084 mg/l	ND	ND	ND	ND	ND	ND	ND	ND
SULFATE	250 mg/l	5.0 mg/l	ND	ND	ND	ND	ND	ND	ND	ND
FREE CYANIDE	200 ug/l	<10.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
ANTIMONY	6.0 ug/l	5.9 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
BERYLLIUM	4.0 ug/l	3.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
CALCIUM	None	0.2 mg/l	4.7/ND	4.7/ND	6.7	6.7	2.3	2.3	13.2	13.2
MAGNESIUM	None	0.2 mg/l	2.0/ND	2.0/ND	1.6	1.6	0.4	0.4	1.8	1.8
NICKEL	0.10 mg/l	0.04 mg/l	ND	ND	ND	ND	ND	ND	ND	ND
THALLIUM	2.0 ug/l	1.9 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
PERCHLORATE	18 ug/l	4.0 ug/l	5.6 <sup>(2)</sup> /ND	5.5/ND	4.1	4.1			2.3 <sup>(2)</sup>	1.8

CONT. - CONTAMINANT

ND - NOT DETECTED

\*\* - 20 mg/l IS THE LIMIT FOR PEOPLE ON HIGHLY RESTRICTED SODIUM DIETS AND 270 mg/l FOR THOSE ON MODERATELY RESTRICTED SODIUM DIETS

[ ] - USEPA/NYS DH ACTION LEVEL

<sup>(1)</sup> ONE SAMPLE WAS TAKEN FROM WELL

<sup>(2)</sup> TWO SAMPLES WERE TAKEN FROM WELL

**PLAINVIEW WATER DISTRICT  
2003 WATER QUALITY DATA**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095 <sup>(1)</sup>		WELL NO. 1-2 N-4096 <sup>(1)</sup>		WELL NO. 2-1 N-7526 <sup>(1)</sup>		WELL NO. 3-1 N-4097	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b><u>SYNTHETIC ORGANICS (SOC)</u></b>										
LINDANE	0.2 ug/l	0.025 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	SERVICE
HEPTACHLOR	0.4 ug/l	0.025 ug/l	ND	ND	ND	ND	ND	ND		
ALDRIN	5.0 ug/l	0.025 ug/l	ND	ND	ND	ND	ND	ND		
HEPTACHLOR EPOXIDE	0.2 ug/l	0.025 ug/l	ND	ND	ND	ND	ND	ND		
DIELDRIN	2.0 ug/l	0.05 ug/l	ND	ND	ND	ND	ND	ND		
ENDRIN	2.0 ug/l	0.05 ug/l	ND	ND	ND	ND	ND	ND		
METHOXYCHLOR	40.0 ug/l	0.25 ug/l	ND	ND	ND	ND	ND	ND		
TOXAPHENE	3.0 ug/l	2.5 ug/l	ND	ND	ND	ND	ND	ND		
CHLORDANE	2.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
TOTAL PCBs	0.5 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
PROPACHLOR	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND		
ALACHLOR	2.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND		
SIMAZINE	4.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
ATRAZINE	3.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
METOLACHLOR	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND		
METRIBUZIN	50.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
BUTACHLOR	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND		

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 3-1 - OUT OF SERVICE

<sup>(1)</sup> ONE SAMPLE WAS TAKEN FROM WELL

**PLAINVIEW WATER DISTRICT  
2003 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077 <sup>(1)</sup>		WELL NO. 4-3 N-6076 <sup>(1)</sup>		WELL NO. 5-1 N-6956 <sup>(1)</sup>	
			1.8 RESULT	1.8 RESULT	2.7 RESULT	2.7 RESULT	2.3 RESULT	2.3 RESULT	MAX. RESULT	AVG. RESULT
<b><u>SYNTHETIC ORGANICS</u></b> <b><u>(SOC)</u></b>										
LINDANE	0.2 ug/l	0.025 ug/l	OUT OF SERVICE		ND	ND	ND	ND	ND	ND
HEPTACHLOR	0.4 ug/l	0.025 ug/l		ND	ND	ND	ND	ND	ND	ND
ALDRIN	5.0 ug/l	0.025 ug/l		ND	ND	ND	ND	ND	ND	ND
HEPTACHLOR EPOXIDE	0.2 ug/l	0.025 ug/l		ND	ND	ND	ND	ND	ND	ND
DIELDRIN	2.0 ug/l	0.05 ug/l		ND	ND	ND	ND	ND	ND	ND
ENDRIN	2.0 ug/l	0.05 ug/l		ND	ND	ND	ND	ND	ND	ND
METHOXYCHLOR	40.0 ug/l	0.25 ug/l		ND	ND	ND	ND	ND	ND	ND
TOXAPHENE	3.0 ug/l	2.5 ug/l		ND	ND	ND	ND	ND	ND	ND
CHLORDANE	2.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND
TOTAL PCBs	0.5 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND
PROPACHLOR	50.0 ug/l	1.0 ug/l		ND	ND	ND	ND	ND	ND	ND
ALACHLOR	2.0 ug/l	1.0 ug/l		ND	ND	ND	ND	ND	ND	ND
SIMAZINE	4.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND
ATRAZINE	3.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND
METOLACHLOR	50.0 ug/l	1.0 ug/l		ND	ND	ND	ND	ND	ND	ND
METRIBUZIN	50.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
BUTACHLOR	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL 3-2 - OUT OF SERVICE

<sup>(1)</sup> ONE SAMPLE WAS TAKEN FROM WELL

**PLAINVIEW WATER DISTRICT  
2003 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421 <sup>(1)</sup>		WELL NO. 5-3 N-8054 <sup>(1)</sup>		WELL NO. 5-4 N-8595 <sup>(1)</sup>		WELL NO. 7-1 <sup>(1)</sup>	
			MAX. RESULT	AVG. RESULT	MAX.	AVG.	MAX.	AVG.	MAX.	AVG.
<b><u>SYNTHETIC ORGANICS</u></b> <b><u>(SOC)</u></b>										
LINDANE	0.2 ug/l	0.025 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
HEPTACHLOR	0.4 ug/l	0.025 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
ALDRIN	5.0 ug/l	0.025 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
HEPTACHLOR EPOXIDE	0.2 ug/l	0.025 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
DIELDRIN	2.0 ug/l	0.05 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
ENDRIN	2.0 ug/l	0.05 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
METHOXYCHLOR	40.0 ug/l	0.25 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
TOXAPHENE	3.0 ug/l	2.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
CHLORDANE	2.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
TOTAL PCBs	0.5 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
PROPACHLOR	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
ALACHLOR	2.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
SIMAZINE	4.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
ATRAZINE	3.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
METOLACHLOR	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
METRIBUZIN	50.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
BUTACHLOR	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

<sup>(1)</sup> ONE SAMPLE WAS TAKEN FROM WELL

**PLAINVIEW WATER DISTRICT  
2003 WATER QUALITY DATA**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095 <sup>(1)</sup>		WELL NO. 1-2 N-409 <sup>(1)</sup>		WELL NO. 2-1 N-7526 <sup>(1)</sup>		WELL NO. 3-1 N-4097	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b><u>SYNTHETIC ORGANICS (SOC)</u></b> <b><u>(CONT'D.)</u></b>										
2,4-D	50.0 ug/l	0.2 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	SERVICE
2,4,5-TP (SILVEX)	10.0 ug/l	0.05 ug/l	ND	ND	ND	ND	ND	ND		
DINOSEB	7.0 ug/l	0.2 ug/l	ND	ND	ND	ND	ND	ND		
DALAPON	200 ug/l	0.7 ug/l	ND	ND	ND	ND	ND	ND		
PICLORAM	500 ug/l	8.6 ug/l	ND	ND	ND	ND	ND	ND		
DICAMBA	50.0 ug/l	0.08 ug/l	ND	ND	ND	ND	ND	ND		
PENTACHLOROPHENOL	1.0 ug/l	0.2 ug/l	ND	ND	ND	ND	ND	ND		
HEXACHLOROCYCLOPENTADIENE	50.0 ug/l	0.64 ug/l	ND	ND	ND	ND	ND	ND		
bis(2-ETHYLHEXYL)ADIPATE	400 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND		
bis(2-ETHYLHEXYL)PHTHALATE	6.0 ug/l	3.0 ug/l	ND	ND	ND	ND	ND	ND		
HEXACHLOROBENZENE	1.0 ug/l	0.25 ug/l	ND	ND	ND	ND	ND	ND		
BENZO(A)PYRENE	0.2 ug/l	0.1 ug/l	ND	ND	ND	ND	ND	ND		
ALDICARB SULFONE	2.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND		
ALDICARBSULFOXIDE	4.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND		
ALDICARB	3.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND		
TOTAL ALDICARBS	7.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND		
OXAMYL	200 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND		
METHOMYL	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND		
3-HYDROXYCARBOFURAN	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND		
CARBOFURAN	40.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND		
CARBARYL	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND		
GLYPHOSATE	700 ug/l	10.0 ug/l	ND	ND	ND	ND	ND	ND		
DIQUAT	20 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND		
ENDOTHALL	100 ug/l	50.0 ug/l	ND	ND	ND	ND	ND	ND		
1,2-DIBROMOETHANE (EDB)	0.05 ug/l	0.02 ug/l	ND	ND	ND	ND	ND	ND		
1,2-DIBROMO-3-CHL.PROPANE	0.2 ug/l	0.02 ug/l	ND	ND	ND	ND	ND	ND		
DIOXIN	30 Pg/L	5.0 Pg/L	ND	ND	ND	ND	ND	ND		

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 3-1 - OUT OF SERVICE

Pg/L - PICOGRAMS PER LITER

NOT TESTED - STATE AND COUNTY TESTING REQUIREMENTS INCLUDE TESTING FOR SOC ONCE EVERY 18 MONTHS. THIS WELL NOT TESTED IN 2002.

**PLAINVIEW WATER DISTRICT  
2003 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077 <sup>(1)</sup>		WELL NO. 4-3 N-6076 <sup>(1)</sup>		WELL NO. 5-1 N-6956 <sup>(1)</sup>	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b><u>SYNTHETIC ORGANICS (SOC)</u></b> <b><u>(CONT'D.)</u></b>			<b>OUT OF SERVICE</b>		ND	ND	ND	ND	ND	ND
2,4-D	50.0 ug/l	0.2 ug/l			ND	ND	ND	ND	ND	ND
2,4,5-TP (SILVEX)	10.0 ug/l	0.05 ug/l			ND	ND	ND	ND	ND	ND
DINOSEB	7.0 ug/l	0.2 ug/l			ND	ND	ND	ND	ND	ND
DALAPON	200 ug/l	0.7 ug/l			ND	ND	ND	ND	ND	ND
PICLORAM	500 ug/l	8.6 ug/l			ND	ND	ND	ND	ND	ND
DICAMBA	50.0 ug/l	0.08 ug/l			ND	ND	ND	ND	ND	ND
PENTACHLOROPHENOL	1.0 ug/l	0.2 ug/l			ND	ND	ND	ND	ND	ND
HEXACHLOROCYCLOPENTADIENE	50.0 ug/l	0.64 ug/l			ND	ND	ND	ND	ND	ND
bis(2-ETHYLHEXYL)ADIPATE	400 ug/l	1.0 ug/l			ND	ND	ND	ND	ND	ND
bis(2-ETHYLHEXYL)PHTHALATE	6.0 ug/l	3.0 ug/l			ND	ND	ND	ND	ND	ND
HEXACHLOROBENZENE	1.0 ug/l	0.25 ug/l			ND	ND	ND	ND	ND	ND
BENZO(A)PYRENE	0.2 ug/l	0.1 ug/l			ND	ND	ND	ND	ND	ND
ALDICARB SULFONE	2.0 ug/l	1.0 ug/l			ND	ND	ND	ND	ND	ND
ALDICARBSULFOXIDE	4.0 ug/l	1.0 ug/l			ND	ND	ND	ND	ND	ND
ALDICARB	3.0 ug/l	1.0 ug/l			ND	ND	ND	ND	ND	ND
TOTAL ALDICARBS	7.0 ug/l	1.0 ug/l			ND	ND	ND	ND	ND	ND
OXAMYL	200 ug/l	1.0 ug/l			ND	ND	ND	ND	ND	ND
METHOMYL	50.0 ug/l	1.0 ug/l			ND	ND	ND	ND	ND	ND
3-HYDROXYCARBOFURAN	50.0 ug/l	1.0 ug/l			ND	ND	ND	ND	ND	ND
CARBOFURAN	40.0 ug/l	1.0 ug/l			ND	ND	ND	ND	ND	ND
CARBARYL	50.0 ug/l	1.0 ug/l			ND	ND	ND	ND	ND	ND
GLYPHOSATE	700 ug/l	10.0 ug/l			ND	ND	ND	ND	ND	ND
DIQUAT	20 ug/l	1.0 ug/l			ND	ND	ND	ND	ND	ND
ENDOTHALL	100 ug/l	50.0 ug/l			ND	ND	ND	ND	ND	ND
1,2-DIBROMOETHANE (EDB)	0.05 ug/l	0.02 ug/l			ND	ND	ND	ND	ND	ND
1,2-DIBROMO-3-CHL.PROPANE	0.2 ug/l	0.02 ug/l			ND	ND	ND	ND	ND	ND
DIOXIN	30 Pg/L	5.0 Pg/L			ND	ND	ND	ND	ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

Pg/L - PICOGRAMS PER LITER

NOT TESTED - STATE AND COUNTY TESTING REQUIREMENTS INCLUDE TESTING FOR SOC ONCE EVERY 18 MONTHS. THIS WELL NOT TESTED IN 2002.

WELL NO. 3-2 - OUT OF SERVICE

**PLAINVIEW WATER DISTRICT  
2003 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421 <sup>(1)</sup>		WELL NO. 5-3 N-8054 <sup>(1)</sup>		WELL NO. 5-4 N-8595 <sup>(1)</sup>		WELL NO. 7-1 <sup>(1)</sup>	
			MAX. RESULT	AVG. RESULT	ND RESULT	ND RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b><u>SYNTHETIC ORGANICS (SOC)</u></b>										
<b><u>(CONT'D.)</u></b>										
2,4-D	50.0 ug/l	0.2 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
2,4,5-TP (SILVEX)	10.0 ug/l	0.05 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
DINOSEB	7.0 ug/l	0.2 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
DALAPON	200 ug/l	0.7 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
PICLORAM	500 ug/l	8.6 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
DICAMBA	50.0 ug/l	0.08 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
PENTACHLOROPHENOL	1.0 ug/l	0.2 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
HEXACHLOROCYCLOPENTADIENE	50.0 ug/l	0.64 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
bis(2-ETHYLHEXYL)ADIPATE	400 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
bis(2-ETHYLHEXYL)PHTHALATE	6.0 ug/l	3.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
HEXACHLOROENZENE	1.0 ug/l	0.25 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
BENZO(A)PYRENE	0.2 ug/l	0.1 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
ALDICARB SULFONE	2.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
ALDICARBSULFOXIDE	4.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
ALDICARB	3.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
TOTAL ALDICARBS	7.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
OXAMYL	200 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
METHOMYL	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
3-HYDROXYCARBOFURAN	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
CARBOFURAN	40.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
CARBARYL	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
GLYPHOSATE	700 ug/l	10.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
DIQUAT	20 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
ENDOTHALL	100 ug/l	50.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
1,2-DIBROMOETHANE (EDB)	0.05 ug/l	0.02 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
1,2-DIBROMO-3-CHL.PROPANE	0.2 ug/l	0.02 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
DIOXIN	30 Pg/L	5.0 Pg/L	ND	ND	ND	ND	ND	ND	ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 5-3 - OUT OF SERVICE

Pg/L - PICOGRAMS PER LITER

NOT TESTED - STATE AND COUNTY TESTING REQUIREMENTS INCLUDE TESTING FOR SOC ONCE EVERY 18 MONTHS. THIS WELL NOT TESTED IN 2002.

<sup>(1)</sup> ONE SAMPLE WAS TAKEN FROM WELL

PLAINVIEW WATER DISTRICT  
2003 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095 <sup>(4)</sup>		WELL NO. 1-2 N-4096 <sup>(4)</sup>		WELL NO. 2-1 N-7526 <sup>(4)</sup>		WELL NO. 3-1 N-4097	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b><u>VOLATILE ORGANICS</u></b>										
DICHLORODIFLUOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	OUT OF SERVICE
CHLOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
VINYL CHLORIDE	2.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
BROMOMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
CHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
TRICHLOROFLUOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,1-DICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	0.7	0.2	ND	
METHYLENE CHLORIDE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
TRANS-1,2-DICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,1-DICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
<i>cis</i> -1,2 DICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
2,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
BROMOCHLOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
CHLOROFORM	50 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,1,1-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	0.8	0.2	2.3	0.9	ND	
CARBON TETRACHLORIDE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,1-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,2-DICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
TRICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
DIBROMOMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
BROMODICHLOROMETHANE	50 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
TRANS-1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
<i>cis</i> -1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,1,2-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
TETRACHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 3-1 - OUT OF SERVICE

<sup>(4)</sup> FOUR SAMPLES WERE TAKEN FROM WELL

PLAINVIEW WATER DISTRICT  
2003 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095 <sup>(4)</sup>		WELL NO. 1-2 N-4096 <sup>(4)</sup>		WELL NO. 2-1 N-7526 <sup>(4)</sup>		WELL NO. 3-1 N-4097	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b><u>VOLATILE ORGANICS (CONT'D.)</u></b>										
1,3-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
DIBROMOCHLOROMETHANE	50 ug/l	0.5 ug/l	ND	ND	ND	ND	0.5	0.1		
CHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,1,1,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
BROMOFORM	50 ug/l	0.5 ug/l	ND	ND	ND	ND	0.6	0.1		
BROMOBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,1,2,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,2,3-TRICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
2-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
4-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
M-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
P-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
O-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,2,4-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
HEXACHLOROBUTADIENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,2,3-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
BENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
TOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
ETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,3-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,4-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,2-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
STYRENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
ISOPROPYLBENZENE (CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
N-PROPYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,3,5-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 3-1 - OUT OF SERVICE

<sup>(4)</sup> FOUR SAMPLES WERE TAKEN FROM WELL

**PLAINVIEW WATER DISTRICT  
2003 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095 <sup>(4)</sup>		WELL NO. 1-2 N-4096 <sup>(4)</sup>		WELL NO. 2-1 N-7526 <sup>(4)</sup>		WELL NO. 3-1 N-4097	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b><u>VOLATILE ORGANICS (CONT'D.)</u></b>										
TERT-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	OUT OF SERVICE
1,2,4-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
SEC-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
P-ISOPROPYLTOLUENE (P-CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
N-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
METHLY TERT.BUTYL ETHER	10.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 3-1 - OUT OF SERVICE

<sup>(4)</sup> FOUR SAMPLES WERE TAKEN FROM WELL

PLAINVIEW WATER DISTRICT  
2003 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077 <sup>(30)</sup>		WELL NO. 4-3 N-6076 <sup>(4)</sup>		WELL NO. 5-1 N-6956 <sup>(29)</sup>		
			MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	
<b><u>VOLATILE ORGANICS</u></b>											
DICHLORODIFLUOROMETHANE	5.0 ug/l	0.5 ug/l	OUT OF SERVICE		0.7/ND	0.1/ND	ND	ND	ND	ND	
CHLOROMETHANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	
VINYL CHLORIDE	2.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	
BROMOMETHANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	
CHLOROETHANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	
TRICHLOROFLUOROMETHANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	
1,1-DICHLOROETHENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	
METHYLENE CHLORIDE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	
TRANS-1,2-DICHLOROETHENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	
1,1-DICHLOROETHANE	5.0 ug/l	0.5 ug/l				2.3/ND	0.9/ND	ND	ND	0.7/ND	0.1/ND
<i>cis</i> -1,2-DICHLOROETHENE	5.0 ug/l	0.5 ug/l				ND	ND	ND	ND	ND	ND
2,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l				ND	ND	ND	ND	ND	ND
BROMOCHLOROMETHANE	5.0 ug/l	0.5 ug/l				ND	ND	ND	ND	ND	ND
CHOLORFORM	50 ug/l	0.5 ug/l				ND	ND	ND	ND	1.2/ND	0.6/ND
1,1,1-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l				1.5/ND	0.6/ND	ND	ND	0.6/ND	0.2/ND
CARBON TETRACHLORIDE	5.0 ug/l	0.5 ug/l				ND	ND	ND	ND	ND	ND
1,1-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l				ND	ND	ND	ND	ND	ND
1,2-DICHLOROETHANE	5.0 ug/l	0.5 ug/l				ND	ND	ND	ND	ND	ND
TRICHLOROETHENE	5.0 ug/l	0.5 ug/l				2.3/ND	0.9/ND	ND	ND	0.6/ND	0.04/ND
1,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l				ND	ND	ND	ND	ND	ND
DIBROMOMETHANE	5.0 ug/l	0.5 ug/l				ND	ND	ND	ND	ND	ND
BROMODICHLOROMETHANE	50 ug/l	0.5 ug/l				ND	ND	ND	ND	0.8/ND	0.06/ND
TRANS-1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l				ND	ND	ND	ND	ND	ND
<i>cis</i> -1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	
1,1,2-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	
TETRACHLOROETHENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 3-2 - OUT OF SERVICE

<sup>(4)</sup> FOUR SAMPLES WERE TAKEN FROM WELL

<sup>(25)</sup> TWENTY-FIVE SAMPLES WERE TAKEN FROM WELL

<sup>(29)</sup> TWENTY-NINE SAMPLES WERE TAKEN FROM WELL

PLAINVIEW WATER DISTRICT  
2003 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077 <sup>(30)</sup>		WELL NO. 4-3 N-6076 <sup>(4)</sup>		WELL NO. 5-1 N-6956 <sup>(29)</sup>	
			MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)
<b><u>VOLATILE ORGANICS (CONT'D.)</u></b>			<b>OUT OF SERVICE</b>		ND	ND	ND	ND	ND	ND
1,3-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	0.5/ND	0.04/ND
DIBROMOCHLOROMETHANE	50 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
CHLOROBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
1,1,1,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
BROMOFORM	50 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
BROMOBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
1,1,2,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
1,2,3-TRICHLOROPROPANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
2-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
4-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
M-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
P-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
O-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
1,2,4-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
HEXACHLOROBUTADIENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
1,2,3-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
BENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
TOLUENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
ETHYLBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
1,3-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,4-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,2-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
STYRENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
ISOPROPYLBENZENE (CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
N-PROPYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,3,5-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 3-2 - OUT OF SERVICE

<sup>(4)</sup> FOUR SAMPLES WERE TAKEN FROM WELL

<sup>(25)</sup> TWENTY-FIVE SAMPLES WERE TAKEN FROM WELL

<sup>(29)</sup> TWENTY-NINE SAMPLES WERE TAKEN FROM WELL

**PLAINVIEW WATER DISTRICT  
2003 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077 <sup>(30)</sup>		WELL NO. 4-3 N-6076 <sup>(4)</sup>		WELL NO. 5-1 N-6956 <sup>(29)</sup>	
			MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)
<b><u>VOLATILE ORGANICS (CONT'D.)</u></b>										
TERT-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	<b>OUT OF SERVICE</b>		ND	ND	ND	ND	ND	ND
1,2,4-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	
SEC-BUTYLBENZENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	
P-ISOPROPYLTOLUENE (P-CUMENE)	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	
N-BUTYLBENZENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	
METHLY TERT.BUTYL ETHER	10.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 3-2 - OUT OF SERVICE

<sup>(4)</sup> FOUR SAMPLES WERE TAKEN FROM WELL

<sup>(25)</sup> TWENTY-FIVE SAMPLES WERE TAKEN FROM WELL

<sup>(29)</sup> TWENTY-NINE SAMPLES WERE TAKEN FROM WELL

PLAINVIEW WATER DISTRICT  
2003 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421 <sup>(31)</sup>		WELL NO. 5-3 N-8054 <sup>(4)</sup>		WELL NO. 5-4 N-8595 <sup>(3)</sup>		WELL NO. 7-1 <sup>(4)</sup>	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b><u>VOLATILE ORGANICS</u></b>										
DICHLORODIFLUOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
CHLOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
VINYL CHLORIDE	2.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
BROMOMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
CHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
TRICHLOROFLUOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
1,1-DICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
METHYLENE CHLORIDE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
TRANS-1,2-DICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
1,1-DICHLOROETHANE	5.0 ug/l	0.5 ug/l	1.0/ND	0.3/ND	ND	ND	ND	ND	ND	ND
<i>cis</i> -1,2 DICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
2,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
BROMOCHLOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
CHOLORFORM	50 ug/l	0.5 ug/l	3.6/ND	1.5/ND	ND	ND	ND	ND	ND	ND
1,1,1-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l	1.5/ND	0.6/ND	ND	ND	ND	ND	0.5	0.1
CARBON TETRACHLORIDE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
1,1-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
1,2-DICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
TRICHLOROETHENE	5.0 ug/l	0.5 ug/l	1.2/ND	0.3/ND	ND	ND	ND	ND	4.0	2.3
1,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	1.3/ND	0.2/ND	ND	ND	ND	ND	ND	ND
DIBROMOMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
BROMODICHLOROMETHANE	50 ug/l	0.5 ug/l	1.5/ND	0.1/ND	0.7	0.2	ND	ND	ND	ND
TRANS-1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
<i>cis</i> -1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
1,1,2-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
TETRACHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

<sup>(3)</sup> THREE SAMPLES WERE TAKEN FROM WELL

<sup>(4)</sup> FOUR SAMPLES WERE TAKEN FROM WELL

<sup>(31)</sup> THIRTY-ONE SAMPLES WERE TAKEN FROM WELL

PLAINVIEW WATER DISTRICT  
2003 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421 <sup>(6)</sup>		WELL NO. 5-3 N-8054 <sup>(4)</sup>		WELL NO. 5-4 N-8595 <sup>(3)</sup>		WELL NO. 7-1 <sup>(4)</sup>	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b><u>VOLATILE ORGANICS (CONT'D.)</u></b>										
1,3-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
DIBROMOCHLOROMETHANE	50 ug/l	0.5 ug/l	1.2/ND	0.1/ND	1.9	0.7	ND	ND	ND	ND
CHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
1,1,1,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
BROMOFORM	50 ug/l	0.5 ug/l	0.5/ND	0.03/ND	3.5	1.2	ND	ND	ND	ND
BROMOBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
1,1,2,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
1,2,3-TRICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
2-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
4-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
M-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
P-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
O-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
1,2,4-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
HEXACHLOROBUTADIENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
1,2,3-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
BENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
TOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
ETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
1,3-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
1,4-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
1,2-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
STYRENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
ISOPROPYLBENZENE (CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
N-PROPYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
1,3,5-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

<sup>(3)</sup> THREE SAMPLES WERE TAKEN FROM WELL

<sup>(4)</sup> FOUR SAMPLES WERE TAKEN FROM WELL

<sup>(31)</sup> THIRTY-ONE SAMPLES WERE TAKEN FROM WELL

**PLAINVIEW WATER DISTRICT  
2003 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421 <sup>(6)</sup>		WELL NO. 5-3 N-8054 <sup>(4)</sup>		WELL NO. 5-4 N-8595 <sup>(3)</sup>		WELL NO. 7-1 <sup>(4)</sup>	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b><u>VOLATILE ORGANICS (CONT'D.)</u></b>										
TERT-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
1,2,4-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
SEC-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
P-ISOPROPYLTOLUENE (P-CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
N-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND
METHLY TERT.BUTYL ETHER	10.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

<sup>(3)</sup> THREE SAMPLES WERE TAKEN FROM WELL

<sup>(4)</sup> FOUR SAMPLES WERE TAKEN FROM WELL

<sup>(31)</sup> THIRTY-ONE SAMPLES WERE TAKEN FROM WELL