

**PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA**

PARAMETERS (mg/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095 <sup>(1)</sup>		WELL NO. 1-2 N-4096 <sup>(1)</sup>		WELL NO. 2-1 N-7526 <sup>(2)</sup>		WELL NO. 3-1 N-4097	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT
<b>INORGANIC</b>										
ARSENIC	10.0 ug/l	3.0 ug/l	ND	ND	ND	ND	ND	ND	<b>OUT OF SERVICE</b>	
BARIUM	2.0 mg/l	0.2 mg/l	ND	ND	ND	ND	ND	ND		
CADMIUM	5.0 ug/l	5.0 ug/l	ND	ND	ND	ND	ND	ND		
CHROMIUM	0.10 mg/l	0.01 mg/l	ND	ND	ND	ND	ND	ND		
COPPER	[1.3] mg/l	0.02 mg/l	ND	ND	ND	ND	ND	ND		
FLUORIDE	2.2 mg/l	0.1 mg/l	ND	ND	ND	ND	ND	ND		
LEAD	[15.0] ug/l	1.0 ug/l	ND	ND	7.2	7.2	ND	ND		
MERCURY	2.0 ug/l	0.2 ug/l	ND	ND	ND	ND	ND	ND		
LANGLIER SATURATION INDEX	None	None	-4.30	-4.30	-4.85	-4.85	-5.20/-3.47	-5.20/-3.47		
SELENIUM	50 ug/l	5.0 ug/l	ND	ND	ND	ND	ND	ND		
SILVER	0.1 mg/l	0.01 mg/l	ND	ND	ND	ND	ND	ND		
SODIUM	**20/270 mg/l	0.2 mg/l	3.5	3.5	5.9	5.9	4.1/4.1	4.1/4.1		
ZINC	5.0 mg/l	0.02 mg/l	ND	ND	ND	ND	ND	ND		
COLOR	15 Units	5 Units	ND	ND	ND	ND	ND	ND		
TURBIDITY	5 Units	1 Unit	ND	ND	ND	ND	ND	ND		
ODOR	3 Units	0 Units	ND	ND	ND	ND	ND	ND		
IRON	0.3 mg/l	0.02 mg/l	ND	ND	0.03	0.03	ND	ND		
MANGANESE	0.3 mg/l	0.01 mg/l	ND	ND	ND	ND	ND	ND		
AMMONIA	None	0.1 mg/l	ND	ND	ND	ND	ND	ND		
NITRITE	1.0 mg/l	0.1 mg/l	ND	ND	ND	ND	ND	ND		
NITRATE	10.0 mg/l	0.1 mg/l	1.8	1.8	4.2 <sup>(2)</sup>	2.3	2.4 <sup>(3)</sup> /2.4	2.3/2.4		
CHLORIDE	250 mg/l	1.0 mg/l	4.7	4.7	8.2	8.2	4.7/4.9	4.7/4.9		
TOTAL HARDNESS	None	1.0 mg/l	8.7	8.7	15.1	15.1	8.8/10.2	8.8/10.2		
TOTAL ALKALINITY	None	0 mg/l	2.7	2.7	2.1	2.1	2.0/2.8	2.0/2.8		
pH (BEFORE TREATMENT)	None	None	6.3	6.3	5.7	5.7	5.6/7.1	5.6/7.1		
TOTAL DISSOLVED SOLIDS	None	5.0 mg/l	35.00	35.00	55.0	55.0	34.0/33.0	34.0/33.0		
<b>WELL NO. 1-3 - NOT IN SERVICE DURING 2007</b>										
DETERGENTS (MBAS)	None	0.08 mg/l	ND	ND	ND	ND	ND	ND		
SULFATE	250 mg/l	5.0 mg/l	ND	ND	ND	ND	ND	ND		
FREE CYANIDE	200 ug/l	10.0 ug/l	ND	ND	ND	ND	ND	ND		
ANTIMONY	6.0 ug/l	5.9 ug/l	ND	ND	ND	ND	ND	ND		
BERYLLIUM	4.0 ug/l	3.0 ug/l	ND	ND	ND	ND	ND	ND		
CALCIUM	None	1.0 mg/l	2.7	2.7	4.0	4.0	2.3/2.9	2.3/2.9		
MAGNESIUM	None	1.0 mg/l	0.5	0.5	1.3	1.3	0.8/0.8	0.8/0.8		
NICKEL	0.10 mg/l	0.04 mg/l	ND	ND	ND	ND	ND	ND		
THALLIUM	2.0 ug/l	1.9 ug/l	ND	ND	ND	ND	ND	ND		
PERCHLORATE	18 ug/l	1.0 ug/l	1.4	1.4	ND	ND	2.3 <sup>(2)</sup> /ND	2.2/ND		

CONT. - CONTAMINANT

ND - NOT DETECTED

\*\* - 20 mg/l IS THE LIMIT FOR PEOPLE ON HIGHLY RESTRICTED SODIUM DIETS AND 270 mg/l FOR THOSE ON MODERATELY RESTRICTED SODIUM DIETS

\*\*\* - EXCEEDS NEW YORK STATE/USEPA LIMITS FOR POTABLE WATER

[ ] - USEPA/NYS/DH ACTION LEVEL

WELL NO. 3-1 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA (continued)**

PARAMETERS (mg/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077 <sup>(6)</sup>		WELL NO. 4-3 N-6076 <sup>(5)</sup>		WELL NO. 5-1 N-6956 <sup>(4)</sup>		
			MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	
<b>INORGANIC</b>											
ARSENIC	10.0 ug/l	3.0 ug/l	OUT OF SERVICE		ND	ND	ND	ND	ND	ND	
BARIUM	2.0 mg/l	0.2 mg/l			ND	ND	ND	ND	ND	ND	ND
CADMIUM	5.0 ug/l	5.0 ug/l			ND	ND	ND	ND	ND	ND	ND
CHROMIUM	0.10 mg/l	0.01 mg/l			ND	ND	ND	ND	ND	ND	ND
COPPER	[1.3] mg/l	0.02 mg/l			0.2/0.04	0.1/0.04	ND	ND	0.03/0.02	0.03/0.01	ND
FLUORIDE	2.2 mg/l	0.1 mg/l			ND	ND	ND	ND	ND	ND	ND
LEAD	[15.0] ug/l	1.0 ug/l			5.7/ND	1.9/ND	ND	ND	5.6/11.5	3.9/5.8	ND
MERCURY	2.0 ug/l	0.2 ug/l			ND	ND	ND	ND	ND	ND	ND
LANGLIER SATURATION INDEX	None	None			-8.01/-3.51	-5.40/-3.51	-5.30	-4.98	-6.87/-4.79	-5.98/-4.55	ND
SELENIUM	50 ug/l	5.0 ug/l			ND	ND	ND	ND	ND	ND	ND
SILVER	0.1 mg/l	0.01 mg/l			ND	ND	ND	ND	ND	ND	ND
SODIUM	**20/270 mg/l	0.2 mg/l			14.9/14.7	14.5/14.7	6.2	5.6	7.3/7.6	6.9/7.6	ND
ZINC	5.0 mg/l	0.02 mg/l			0.1/ND	0.1/ND	0.02	0.01	0.02/ND	0.01/ND	ND
COLOR	15 Units	5 Units			ND	ND	ND	ND	ND	ND	ND
TURBIDITY	5 Units	1 Unit			ND	ND	ND	ND	ND	ND	ND
ODOR	3 Units	0 Units			ND	ND	ND	ND	ND	ND	ND
IRON	0.3 mg/l	0.02 mg/l			0.5/0.1	0.1/0.1	ND	ND	0.04/0.03	0.02/0.02	ND
MANGANESE	0.3 mg/l	0.01 mg/l			ND	ND	ND	ND	ND	ND	ND
AMMONIA	None	0.1 mg/l			ND	ND	ND	ND	ND	ND	ND
NITRITE	1.0 mg/l	0.1 mg/l			ND	ND	ND	ND	ND	ND	ND
NITRATE	10.0 mg/l	0.1 mg/l			12.9 <sup>(15)</sup> /7.0 <sup>(3)</sup>	10.6/5.0	6.7 <sup>(15)</sup> /7.0 <sup>(2)</sup>	3.8/5.7	4.2 <sup>(13)</sup> /4.1 <sup>(5)</sup>	2.7/3.9	ND
CHLORIDE	250 mg/l	1.0 mg/l			22.0/22.3	21.5/22.3	6.8	6.7	10.5/10.7	9.9/10.6	ND
TOTAL HARDNESS	None	1.0 mg/l			45.4/45.7	44.7/45.7	14.9	13.1	16.3/17.4	14.4/16.8	ND
TOTAL ALKALINITY	None	0 mg/l			3.6/4.0	2.9/4.0	2.7	2.1	1.9/1.7	1.0/0.9	ND
pH (BEFORE TREATMENT)	None	None	5.3/6.3	5.2/6.3	5.7	5.5	5.5/6.3	5.3/6.2	ND		
TOTAL DISSOLVED SOLIDS	None	5.0 mg/l	185.0/140.0	129.0/140.0	78	47.6	83.0/73.0	68.5/67.0	ND		
DETERGENTS (MBAS)	None	0.08 mg/l	ND	ND	ND	ND	ND	ND	ND		
SULFATE	250 mg/l	5.0 mg/l	5.8/ND	4.3/ND	ND	ND	ND	ND	ND		
FREE CYANIDE	200 ug/l	10.0 ug/l	ND	ND	ND	ND	ND	ND	ND		
ANTIMONY	6.0 ug/l	5.9 ug/l	ND	ND	ND	ND	ND	ND	ND		
BERYLLIUM	4.0 ug/l	3.0 ug/l	ND	ND	ND	ND	ND	ND	ND		
CALCIUM	None	1.0 mg/l	11.6/11.7	11.4/11.7	3.8	3.3	4.0/4.3	3.5/4.0	ND		
MAGNESIUM	None	1.0 mg/l	4.0/4.0	3.9/4.0	1.3	1.2	1.6/1.7	1.4/1.6	ND		
NICKEL	0.10 mg/l	0.04 mg/l	ND	ND	ND	ND	ND	ND	ND		
THALLIUM	2.0 ug/l	1.9 ug/l	ND	ND	ND	ND	ND	ND	ND		
PERCHLORATE	18 ug/l	1.0 ug/l	7.8/5.2	6.6/5.2	4.6 <sup>(5)</sup> /5.2	3.9/5.2	3.6 <sup>(5)</sup> /5.3	3.2/5.3	ND		

ND - NOT DETECTED

**Note:** Well 4-2 is blended with low nitrate Well 4-3 to provide water with nitrate levels below 10 ppm.

\*\*\* - EXCEEDS NEW YORK STATE/USEPA LIMITS FOR POTABLE WATER

\*\* - 20 mg/l IS THE LIMIT FOR PEOPLE ON HIGHLY RESTRICTED SODIUM DIETS AND 270 mg/l FOR THOSE ON MODERATELY RESTRICTED SODIUM DIETS

[ ] - USEPA/NYS/DH ACTION LEVEL

WELL NO. 3-2 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA (continued)**

PARAMETERS (mg/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421 <sup>(4)</sup>		WELL NO. 5-3 N-7421 <sup>(2)</sup>		WELL NO. 5-4 N-8595 <sup>(1)</sup>		WELL NO. 7-1 <sup>(2)</sup>	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)
<b>INORGANIC</b>										
ARSENIC	10.0 ug/l	3.0 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
BARIUM	2.0 mg/l	0.2 mg/l	ND	ND	ND	ND			ND	ND
CADMIUM	5.0 ug/l	5.0 ug/l	ND	ND	ND	ND			ND	ND
CHROMIUM	0.10 mg/l	0.01 mg/l	ND	ND	ND	ND			ND	ND
COPPER	[1.3] mg/l	0.02 mg/l	0.02/0.02	0.02/0.02	0.02/0.02	0.02/0.02			ND	ND
FLUORIDE	2.2 mg/l	0.1 mg/l	ND	ND	ND	ND			ND	ND
LEAD	[15.0] ug/l	1.0 ug/l	5.6/11.5	3.4/5.8	5.6/ND	5.6/ND			ND	ND
MERCURY	2.0 ug/l	0.2 ug/l	ND	ND	ND	ND			ND	ND
LANGLIER SATURATION INDEX	None	None	-5.64/-4.79	-5.37/-4.55	-5.09/-4.31	-5.09/-4.31			-4.71/-4.39	-4.71/-4.39
SELENIUM	50 ug/l	5.0 ug/l	ND	ND	ND	ND			ND	ND
SILVER	0.1 mg/l	0.01 mg/l	ND	ND	ND	ND			ND	ND
SODIUM	**20/270 mg/l	0.2 mg/l	12.0/7.6	9.7/7.6	7.3/7.6	7.3/7.6			2.8/2.9	2.8/2.9
ZINC	5.0 mg/l	0.02 mg/l	0.03/ND	0.02/ND	ND	ND			ND	ND
COLOR	15 Units	5 Units	ND	ND	ND	ND			ND	ND
TURBIDITY	5 Units	1 Unit	ND	ND	ND	ND			ND	ND
ODOR	3 Units	0 Units	ND	ND	ND	ND			ND	ND
IRON	0.3 mg/l	0.02 mg/l	0.04/0.03	0.03/0.02	0.04/0.03	0.04/0.03			***0.4/0.2	***0.4/0.2
MANGANESE	0.3 mg/l	0.01 mg/l	0.01/ND	0.01/ND	ND	ND			0.03/ND	0.03/ND
AMMONIA	None	0.1 mg/l	ND	ND	ND	ND			ND	ND
NITRITE	1.0 mg/l	0.1 mg/l	ND	ND	ND	ND			ND	ND
NITRATE	10.0 mg/l	0.1 mg/l	6.8 <sup>(13)</sup> /4.1 <sup>(5)</sup>	7.5/3.9	4.2/4.1	4.2/4.1			0.3 <sup>(5)</sup> /0.3	0.3/0.3
CHLORIDE	250 mg/l	1.0 mg/l	16.7/10.7	13.6/10.6	10.5/10.4	10.5/10.4			4.0/4.1	4.0/4.1
TOTAL HARDNESS	None	1.0 mg/l	29.9/17.4	23.1/16.8	16.3/17.4	16.3/17.4			3.5/4.1	3.5/4.1
TOTAL ALKALINITY	None	0 mg/l	1.9/1.7	1.0/0.9	1.9/1.7	1.9/1.7			2.6/3.0	2.6/3.0
pH (BEFORE TREATMENT)	None	None	5.5/6.3	5.2/6.2	5.5/6.3	5.5/6.3			6.4/6.6	6.4/6.6
TOTAL DISSOLVED SOLIDS	None	5.0 mg/l	98.0/73.0	90.5/67.0	83.0/73.0	83.0/73.0			28.0/27.0	28.0/27.0
DETERGENTS (MBAS)	None	0.08 mg/l	ND	ND	ND	ND			ND	ND
SULFATE	250 mg/l	5.0 mg/l	8.2/ND	4.1/ND	ND	ND			ND	ND
FREE CYANIDE	200 ug/l	10.0 ug/l	ND	ND	ND	ND			ND	ND
ANTIMONY	6.0 ug/l	5.9 ug/l	ND	ND	ND	ND			ND	ND
BERYLLIUM	4.0 ug/l	3.0 ug/l	ND	ND	ND	ND			ND	ND
CALCIUM	None	1.0 mg/l	6.9/4.3	5.4/4.0	4.0/4.3	4.0/4.3			0.8/1.0	0.8/1.0
MAGNESIUM	None	1.0 mg/l	3.1/1.7	2.3/1.6	1.6/1.7	1.6/1.7			0.4/0.4	0.4/0.4
NICKEL	0.10 mg/l	0.04 mg/l	ND	ND	ND	ND			ND	ND
THALLIUM	2.0 ug/l	1.9 ug/l	ND	ND	ND	ND			ND	ND
PERCHLORATE	18 ug/l	1.0 ug/l	8.6 <sup>(5)</sup> /5.3	7.8/5.3	ND	ND			ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

\*\* - 20 mg/l IS THE LIMIT FOR PEOPLE ON HIGHLY RESTRICTED SODIUM DIETS AND 270 mg/l FOR THOSE ON MODERATELY RESTRICTED SODIUM DIETS

[ ] - USEPA/NYS DH ACTION LEVEL

WELL NO. 5-4 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095		WELL NO. 1-2 N-4096		WELL NO. 2-1 N-7526		WELL NO. 3-1 N-4097	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b>SYNTHETIC ORGANICS CONTAMINANTS (SOC)</b>										
LINDANE	0.2 ug/l	0.025 ug/l	NOT	TESTED	NOT	TESTED	ND	ND	OUT OF	SERVICE
HEPTACHLOR	0.4 ug/l	0.025 ug/l					ND	ND		
ALDRIN	5.0 ug/l	0.025 ug/l					ND	ND		
HEPTACHLOR EPOXIDE	0.2 ug/l	0.025 ug/l					ND	ND		
DIELDRIN	2.0 ug/l	0.05 ug/l					ND	ND		
ENDRIN	2.0 ug/l	0.05 ug/l					ND	ND		
METHOXYCHLOR	40.0 ug/l	0.25 ug/l					ND	ND		
TOXAPHENE	3.0 ug/l	2.5 ug/l					ND	ND		
CHLORDANE	2.0 ug/l	0.5 ug/l					ND	ND		
TOTAL PCBs	0.5 ug/l	0.5 ug/l					ND	ND		
PROPACHLOR	50.0 ug/l	1.0 ug/l					ND	ND		
ALACHLOR	2.0 ug/l	1.0 ug/l					ND	ND		
SIMAZINE	4.0 ug/l	0.5 ug/l					ND	ND		
ATRAZINE	3.0 ug/l	0.5 ug/l					ND	ND		
METOLACHLOR	50.0 ug/l	1.0 ug/l					ND	ND		
METRIBUZIN	50.0 ug/l	0.5 ug/l					ND	ND		
BUTACHLOR	50.0 ug/l	1.0 ug/l					ND	ND		

CONT. - CONTAMINANT

ND - NOT DETECTED

NOT TESTED - STATE AND COUNTY TESTING REQUIREMENTS INCLUDE TESTING FOR SOC ONCE EVERY 18 MONTHS. THIS WELL NOT TESTED IN 2007.

WELL NO. 3-1 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

WELL NO. 1-3 - NOT IN SERVICE DURING 2007

**PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077		WELL NO. 4-3 N-6076		WELL NO. 5-1 N-6956	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b><u>SYNTHETIC ORGANICS CONTAMINANTS</u></b>										
<b><u>(SOC)</u></b>										
LINDANE	0.2 ug/l	0.025 ug/l	<b>OUT OF SERVICE</b>	<b>NOT TESTED</b>	<b>NOT TESTED</b>	<b>NOT TESTED</b>	<b>NOT TESTED</b>	<b>NOT TESTED</b>	<b>NOT TESTED</b>	<b>NOT TESTED</b>
HEPTACHLOR	0.4 ug/l	0.025 ug/l								
ALDRIN	5.0 ug/l	0.025 ug/l								
HEPTACHLOR EPOXIDE	0.2 ug/l	0.025 ug/l								
DIELDRIN	2.0 ug/l	0.05 ug/l								
ENDRIN	2.0 ug/l	0.05 ug/l								
METHOXYCHLOR	40.0 ug/l	0.25 ug/l								
TOXAPHENE	3.0 ug/l	2.5 ug/l								
CHLORDANE	2.0 ug/l	0.5 ug/l								
TOTAL PCBs	0.5 ug/l	0.5 ug/l								
PROPACHLOR	50.0 ug/l	1.0 ug/l								
ALACHLOR	2.0 ug/l	1.0 ug/l								
SIMAZINE	4.0 ug/l	0.5 ug/l								
ATRAZINE	3.0 ug/l	0.5 ug/l								
METOLACHLOR	50.0 ug/l	1.0 ug/l								
METRIBUZIN	50.0 ug/l	0.5 ug/l								
BUTACHLOR	50.0 ug/l	1.0 ug/l								

CONT. - CONTAMINANT

ND - NOT DETECTED

NOT TESTED - STATE AND COUNTY TESTING REQUIREMENTS INCLUDE TESTING FOR SOC ONCE EVERY 18 MONTHS. THIS WELL NOT TESTED IN 2007.

WELL 3-2 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421		WELL NO. 5-3 N-8054		WELL NO. 5-4 N-8595		WELL NO. 7-1	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b><u>SYNTHETIC ORGANICS CONTAMINANTS</u></b>										
<b><u>(SOC)</u></b>										
LINDANE	0.2 ug/l	0.025 ug/l	NOT	TESTED	NOT	TESTED	OUT OF	SERVICE	NOT	TESTED
HEPTACHLOR	0.4 ug/l	0.025 ug/l								
ALDRIN	5.0 ug/l	0.025 ug/l								
HEPTACHLOR EPOXIDE	0.2 ug/l	0.025 ug/l								
DIELDRIN	2.0 ug/l	0.05 ug/l								
ENDRIN	2.0 ug/l	0.05 ug/l								
METHOXYCHLOR	40.0 ug/l	0.25 ug/l								
TOXAPHENE	3.0 ug/l	2.5 ug/l								
CHLORDANE	2.0 ug/l	0.5 ug/l								
TOTAL PCBs	0.5 ug/l	0.5 ug/l								
PROPACHLOR	50.0 ug/l	1.0 ug/l								
ALACHLOR	2.0 ug/l	1.0 ug/l								
SIMAZINE	4.0 ug/l	0.5 ug/l								
ATRAZINE	3.0 ug/l	0.5 ug/l								
METOLACHLOR	50.0 ug/l	1.0 ug/l								
METRIBUZIN	50.0 ug/l	0.5 ug/l								
BUTACHLOR	50.0 ug/l	1.0 ug/l								

CONT. - CONTAMINANT

ND - NOT DETECTED

NOT TESTED - STATE AND COUNTY TESTING REQUIREMENTS INCLUDE TESTING FOR SOC ONCE EVERY 18 MONTHS. THIS WELL NOT TESTED IN 2007.

WELL NO. 5-4 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095		WELL NO. 1-2 N-409		WELL NO. 2-1 N-7526		WELL NO. 3-1 N-4097	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b>SYNTHETIC ORGANICS CONTAMINANTS (SOC)</b>										
<b>(CONT'D.)</b>										
2,4-D	50.0 ug/l	0.25 ug/l	NOT	TESTED	NOT	TESTED	ND	ND	OUT OF	SERVICE
2,4,5-TP (SILVEX)	10.0 ug/l	0.13 ug/l					ND	ND		
DINOSEB	7.0 ug/l	0.2 ug/l					ND	ND		
DALAPON	200 ug/l	0.7 ug/l					ND	ND		
PICLORAM	500 ug/l	0.6 ug/l					ND	ND		
DICAMBA	50.0 ug/l	0.08 ug/l					ND	ND		
PENTACHLOROPHENOL	1.0 ug/l	0.2 ug/l					ND	ND		
HEXACHLOROCYCLOPENTADIENE	50.0 ug/l	0.64 ug/l					ND	ND		
bis(2-ETHYLHEXYL)ADIPATE	400 ug/l	1.0 ug/l					ND	ND		
bis(2-ETHYLHEXYL)PHTHALATE	6.0 ug/l	3.0 ug/l					ND	ND		
HEXACHLOROBENZENE	1.0 ug/l	0.25 ug/l					ND	ND		
BENZO(A)PYRENE	0.2 ug/l	0.1 ug/l					ND	ND		
ALDICARB SULFONE	2.0 ug/l	1.0 ug/l					ND	ND		
ALDICARBSULFOXIDE	4.0 ug/l	1.0 ug/l					ND	ND		
ALDICARB	3.0 ug/l	1.0 ug/l					ND	ND		
TOTAL ALDICARBS	7.0 ug/l	1.0 ug/l					ND	ND		
OXAMYL	200 ug/l	1.0 ug/l					ND	ND		
METHOMYL	50.0 ug/l	1.0 ug/l					ND	ND		
3-HYDROXYCARBOFURAN	50.0 ug/l	1.0 ug/l					ND	ND		
CARBOFURAN	40.0 ug/l	1.0 ug/l					ND	ND		
CARBARYL	50.0 ug/l	1.0 ug/l					ND	ND		
GLYPHOSATE	700 ug/l	10.0 ug/l					ND	ND		
DIQUAT	20 ug/l	1.0 ug/l					ND	ND		
ENDOTHALL	100 ug/l	50.0 ug/l					ND	ND		
1,2-DIBROMOETHANE (EDB)	0.05 ug/l	0.02 ug/l					ND	ND		
<b>WELL NO. 1-3 - NOT IN SERVICE DURING 2007</b>										
1,2-DIBROMO-3-CHLOROPROPANE	0.2 ug/l	0.02 ug/l					ND	ND		
DIOXIN	30 Pg/L	5.0 Pg/L					ND	ND		

CONT. - CONTAMINANT

ND - NOT DETECTED

NOT TESTED - STATE AND COUNTY TESTING REQUIREMENTS INCLUDE TESTING FOR SOC ONCE EVERY 18 MONTHS. THIS WELL NOT TESTED IN 2007.

WELL NO. 3-1 - OUT OF SERVICE

Pg/L - PICOGRAMS PER LITER

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077		WELL NO. 4-3 N-6076		WELL NO. 5-1 N-6956	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b>SYNTHETIC ORGANICS CONTAMINANTS (SOC)</b>										
<b>(CONT'D.)</b>										
2,4-D	50.0 ug/l	0.25 ug/l	OUT OF	SERVICE	NOT	TESTED	NOT	TESTED	NOT	TESTED
2,4,5-TP (SILVEX)	10.0 ug/l	0.13 ug/l								
DINOSEB	7.0 ug/l	0.2 ug/l								
DALAPON	200 ug/l	0.7 ug/l								
PICLORAM	500 ug/l	0.6 ug/l								
DICAMBA	50.0 ug/l	0.08 ug/l								
PENTACHLOROPHENOL	1.0 ug/l	0.2 ug/l								
HEXACHLOROCYCLOPENTADIENE	50.0 ug/l	0.64 ug/l								
bis(2-ETHYLHEXYL)ADIPATE	400 ug/l	1.0 ug/l								
bis(2-ETHYLHEXYL)PHTHALATE	6.0 ug/l	3.0 ug/l								
HEXACHLOROBENZENE	1.0 ug/l	0.25 ug/l								
BENZO(A)PYRENE	0.2 ug/l	0.1 ug/l								
ALDICARB SULFONE	2.0 ug/l	1.0 ug/l								
ALDICARBSULFOXIDE	4.0 ug/l	1.0 ug/l								
ALDICARB	3.0 ug/l	1.0 ug/l								
TOTAL ALDICARBS	7.0 ug/l	1.0 ug/l								
OXAMYL	200 ug/l	1.0 ug/l								
METHOMYL	50.0 ug/l	1.0 ug/l								
3-HYDROXYCARBOFURAN	50.0 ug/l	1.0 ug/l								
CARBOFURAN	40.0 ug/l	1.0 ug/l								
CARBARYL	50.0 ug/l	1.0 ug/l								
GLYPHOSATE	700 ug/l	10.0 ug/l								
DIQUAT	20 ug/l	1.0 ug/l								
ENDOTHALL	100 ug/l	50.0 ug/l								
1,2-DIBROMOETHANE (EDB)	0.05 ug/l	0.02 ug/l								
1,2-DIBROMO-3-CHLOROPROPANE	0.2 ug/l	0.02 ug/l								
DIOXIN	30 Pg/L	5.0 Pg/L								

CONT. - CONTAMINANT

ND - NOT DETECTED

Pg/L - PICOGRAMS PER LITER

NOT TESTED - STATE AND COUNTY TESTING REQUIREMENTS INCLUDE TESTING FOR SOC ONCE EVERY 18 MONTHS. THIS WELL NOT TESTED IN 2007.

WELL NO. 3-2 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421		WELL NO. 5-3 N-8054		WELL NO. 5-4 N-8595		WELL NO. 7-1	
			MAX. RESULT	AVG. RESULT	ND RESULT	ND RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b>SYNTHETIC ORGANICS CONTAMINANTS (SOC) (CONT'D.)</b>										
2,4-D	50.0 ug/l	0.25 ug/l	NOT	TESTED	NOT	TESTED	OUT OF	SERVICE	NOT	TESTED
2,4,5-TP (SILVEX)	10.0 ug/l	0.13 ug/l								
DINOSEB	7.0 ug/l	0.2 ug/l								
DALAPON	200 ug/l	0.7 ug/l								
PICLORAM	500 ug/l	0.6 ug/l								
DICAMBA	50.0 ug/l	0.08 ug/l								
PENTACHLOROPHENOL	1.0 ug/l	0.2 ug/l								
HEXACHLOROCYCLOPENTADIENE	50.0 ug/l	0.64 ug/l								
bis(2-ETHYLHEXYL)ADIPATE	400 ug/l	1.0 ug/l								
bis(2-ETHYLHEXYL)PHTHALATE	6.0 ug/l	3.0 ug/l								
HEXACHLOROBENZENE	1.0 ug/l	0.25 ug/l								
BENZO(A)PYRENE	0.2 ug/l	0.1 ug/l								
ALDICARB SULFONE	2.0 ug/l	1.0 ug/l								
ALDICARBSULFOXIDE	4.0 ug/l	1.0 ug/l								
ALDICARB	3.0 ug/l	1.0 ug/l								
TOTAL ALDICARBS	7.0 ug/l	1.0 ug/l								
OXAMYL	200 ug/l	1.0 ug/l								
METHOMYL	50.0 ug/l	1.0 ug/l								
3-HYDROXYCARBOFURAN	50.0 ug/l	1.0 ug/l								
CARBOFURAN	40.0 ug/l	1.0 ug/l								
CARBARYL	50.0 ug/l	1.0 ug/l								
GLYPHOSATE	700 ug/l	10.0 ug/l								
DIQUAT	20 ug/l	1.0 ug/l								
ENDOTHALL	100 ug/l	50.0 ug/l								
1,2-DIBROMOETHANE (EDB)	0.05 ug/l	0.02 ug/l								
1,2-DIBROMO-3-CHLOROPROPANE	0.2 ug/l	0.02 ug/l								
DIOXIN	30 Pg/L	5.0 Pg/L								

CONT. - CONTAMINANT

ND - NOT DETECTED

Pg/L - PICOGRAMS PER LITER

NOT TESTED - STATE AND COUNTY TESTING REQUIREMENTS INCLUDE TESTING FOR SOC ONCE EVERY 18 MONTHS. THIS WELL NOT TESTED IN 2007.

WELL NO. 5-4 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095 <sup>(8)</sup>		WELL NO. 1-2 N-409 <sup>(11)</sup>		WELL NO. 2-1 N-7526 <sup>(19)</sup>		WELL NO. 3-1 N-4097	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b><u>TRIHALOMETHANES AND HALOACETIC ACIDS</u></b>										
CHLOROACETIC ACID	---	< 2.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	
BROMOACETIC ACID	---	< 1.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	
DICHLOROACETIC ACID	---	< 1.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	
TRICHLOROACETIC ACID	---	< 1.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	
DIBROMOACETIC ACID	---	< 2.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	
TOTAL HALOACETIC ACID	60 ug/l	< 2.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	
CHLOROFORM	50 ug/l	< 0.5 ug/l	1.7	0.2	2.0	0.5	ND	ND	OUT OF SERVICE	
BROMODICHLOROMETHANE	50 ug/l	< 0.5 ug/l	2.8	0.5	1.7	0.4	ND	ND	OUT OF SERVICE	
DIBROMOCHLOROMETHANE	50 ug/l	< 0.5 ug/l	4.1	0.7	1.9	0.4	ND	ND	OUT OF SERVICE	
BROMOFORM	50 ug/l	< 0.5 ug/l	2.0	0.4	1.7	0.2	ND	ND	OUT OF SERVICE	
TOTAL TRIHALOMETHANES	80 ug/l	< 1.0 ug/l	10.6	1.8	7.3	1.5	ND	ND	OUT OF SERVICE	
<b><u>RADIONUCLIDES</u></b>										
GROSS ALPHA	15 pCi/L	< 3 pCi/L	NOT TESTED	NOT TESTED	0.1 <sup>(1)</sup>	0.1	NOT TESTED	NOT TESTED	OUT OF SERVICE	
GROSS BETA	4 pCi/L	< 3 pCi/L	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	
RADIUM 228	---	< 3 pCi/L	NOT TESTED	NOT TESTED	0.6 <sup>(1)</sup>	0.6	NOT TESTED	NOT TESTED	OUT OF SERVICE	

CONT. - CONTAMINANT

ND - NOT DETECTED

pCi/L - pico Curies per Liter

WELL NO. 3-1 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA (continued)**

WELL NO. 1-3 - NOT IN SERVICE DURING 2007

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077 <sup>(24)</sup>		WELL NO. 4-3 N-6076 <sup>(8)</sup>		WELL NO. 5-1 N-6956 <sup>(26)</sup>		
			MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)	MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)	MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)	
<b><u>TRihalOMETHANES AND HALOACETIC ACIDS</u></b>											
CHLOROACETIC ACID	---	< 2.0 ug/l	OUT OF SERVICE	SERVICE	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
BROMOACETIC ACID	---	< 1.0 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED
DICHLOROACETIC ACID	---	< 1.0 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED
TRICHLOROACETIC ACID	---	< 1.0 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED
DIBROMOACETIC ACID	---	< 2.0 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED
TOTAL HALOACETIC ACID	60 ug/l	< 2.0 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED
CHLOROFORM	50 ug/l	< 0.5 ug/l			0.6/0.6	0.3/0.1	ND/0.6	ND/0.3	1.0/ND	0.4/ND	
BROMODICHLOROMETHANE	50 ug/l	< 0.5 ug/l			ND	ND	ND	ND	1.0/ND	0.1/ND	
DIBROMOCHLOROMETHANE	50 ug/l	< 0.5 ug/l			ND	ND	ND	ND	1.6/ND	0.1/ND	
BROMOFORM	50 ug/l	< 0.5 ug/l			ND	ND	ND	ND	1.3/0.8	0.1/0.1	
TOTAL TRIHALOMETHANES	80 ug/l	< 1.0 ug/l	0.6/0.6	0.3	ND/0.6	ND/0.3	4.9/0.8	0.7/0.1			
<b><u>RADIONUCLIDES</u></b>											
GROSS ALPHA	15 pCi/L	< 3 pCi/L			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
GROSS BETA	4 pCi/L	< 3 pCi/L			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
RADIUM 228	---	< 3 pCi/L			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	

ND - NOT DETECTED

WELL NO. 3-2 - OUT OF SERVICE

pCi/L - pico Curies per Liter

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421 <sup>(16)</sup>		WELL NO. 5-3 N-8054 <sup>(3)</sup>		WELL NO. 5-4 N-8595 <sup>(1)</sup>		WELL NO. 7-1 <sup>(25)</sup>	
			MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)	ND RESULT (Raw/Treated)	ND RESULT (Raw/Treated)	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)
<b><u>TRihalOMETHANES AND HALOACETIC ACIDS</u></b>										
CHLOROACETIC ACID	---	< 2.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE		NOT TESTED	NOT TESTED
BROMOACETIC ACID	---	< 1.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED			NOT TESTED	NOT TESTED
DICHLOROACETIC ACID	---	< 1.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED			NOT TESTED	NOT TESTED
TRICHLOROACETIC ACID	---	< 1.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED			NOT TESTED	NOT TESTED
DIBROMOACETIC ACID	---	< 2.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED			NOT TESTED	NOT TESTED
TOTAL HALOACETIC ACID	60 ug/l	< 2.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED			NOT TESTED	NOT TESTED
CHLOROFORM	50 ug/l	< 0.5 ug/l	4.1/ND	2.0/ND	1.0/ND	0.5/ND			1.3/ND	0.9/ND
BROMODICHLOROMETHANE	50 ug/l	< 0.5 ug/l	ND	ND	ND	ND	ND	ND		
DIBROMOCHLOROMETHANE	50 ug/l	< 0.5 ug/l	ND	ND	0.5/ND	0.3/ND	ND	ND		
BROMOFORM	50 ug/l	< 0.5 ug/l	ND/0.6	ND/0.1	ND	ND	ND	ND		
TOTAL TRIHALOMETHANES	80 ug/l	< 1.0 ug/l	4.1/0.6	2.0/0.1	1.5/ND	0.8/ND	1.3/ND	0.9/ND		
<b><u>RADIONUCLIDES</u></b>										
GROSS ALPHA	15 pCi/L	< 3 pCi/L	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
GROSS BETA	4 pCi/L	< 3 pCi/L	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
RADIUM 228	---	< 3 pCi/L	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	

CONT. - CONTAMINANT

ND - NOT DETECTED

pCi/L - pico Curies per Liter

WELL NO. 5-4 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095 <sup>(8)</sup>		WELL NO. 1-2 N-4096 <sup>(11)</sup>		WELL NO. 2-1 N-7526 <sup>(19)</sup>		WELL NO. 3-1 N-4097	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)	MAX. RESULT	AVG. RESULT
<b><u>VOLATILE ORGANICS</u></b>										
DICHLORODIFLUOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
CHLOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
VINYL CHLORIDE	2.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
BROMOMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
CHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
TRICHLOROFLUOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,1-DICHLOROETHENE	5.0 ug/l	0.5 ug/l	1.4	0.5	***5.5	3.3	***16.4/ND	***8.6/ND		
METHYLENE CHLORIDE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
TRANS-1,2-DICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,1-DICHLOROETHANE	5.0 ug/l	0.5 ug/l	1.4	0.8	3.3	2.5	0.7/ND	0.3/ND		
<i>cis</i> -1,2 DICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
2,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
BROMOCHLOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,1,1-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l	1.2	0.6	***6.0	4.0	***19.6/ND	***11.4/ND		
CARBON TETRACHLORIDE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,1-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,2-DICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
TRICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	2.0	1.4	4.4/ND	3.0/ND		
1,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
DIBROMOMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
TRANS-1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
<i>cis</i> -1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,1,2-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
TETRACHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	1.5	0.9	1.7/ND	0.8/ND		

CONT. - CONTAMINANT

ND - NOT DETECTED

\*\*\* - EXCEEDS NEW YORK STATE/USEPA LIMITS FOR POTABLE WATER

WELL NO. 1-2 - NOT IN SERVICE DURING 2007

WELL NO. 3-1 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095 <sup>(8)</sup>		WELL NO. 1-2 N-4096 <sup>(11)</sup>		WELL NO. 2-1 N-7526 <sup>(19)</sup>		WELL NO. 3-1 N-4097	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)	MAX. RESULT	AVG. RESULT
<b><u>VOLATILE ORGANICS (CONT'D.)</u></b>										
1,3-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
CHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,1,1,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
BROMOBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,1,2,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,2,3-TRICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
2-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
4-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,2-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,3-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,4-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,2,4-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
HEXACHLOROBUTADIENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,2,3-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
BENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
TOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	4.4	0.4	ND	ND		
ETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
M,P-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
O-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
STYRENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
ISOPROPYLBENZENE (CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
N-PROPYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,3,5-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 1-2 - NOT IN SERVICE DURING 2007

WELL NO. 3-1 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095 <sup>(8)</sup>		WELL NO. 1-2 N-4096 <sup>(11)</sup>		WELL NO. 2-1 N-7526 <sup>(19)</sup>		WELL NO. 3-1 N-4097	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)	MAX. RESULT	AVG. RESULT
<b><u>VOLATILE ORGANICS (CONT'D.)</u></b>										
TERT-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	<b>OUT OF SERVICE</b>	
1,2,4-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND			
SEC-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND			
4-ISOPROPYLTOLUENE (P-CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND			
N-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND			
METHYL TERT.BUTYL ETHER (MTBE)	10.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND			

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 1-2 - NOT IN SERVICE DURING 2007

WELL NO. 3-1 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077 <sup>(24)</sup>		WELL NO. 4-3 N-6076 <sup>(8)</sup>		WELL NO. 5-1 N-6956 <sup>(28)</sup>		
			MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	
<b><u>VOLATILE ORGANICS</u></b>											
DICHLORODIFLUOROMETHANE	5.0 ug/l	0.5 ug/l	OUT OF SERVICE		ND	ND	ND	ND	ND	ND	
CHLOROMETHANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	
VINYL CHLORIDE	2.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	
BROMOMETHANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	
CHLOROETHANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	
TRICHLOROFLUOROMETHANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	
1,1-DICHLOROETHENE	5.0 ug/l	0.5 ug/l				2.0/ND	1.2/ND	ND	ND	ND	ND
METHYLENE CHLORIDE	5.0 ug/l	0.5 ug/l				ND	ND	ND	ND	ND	ND
TRANS-1,2-DICHLOROETHENE	5.0 ug/l	0.5 ug/l				ND	ND	ND	ND	ND	ND
1,1-DICHLOROETHANE	5.0 ug/l	0.5 ug/l				4.9/ND	3.7/ND	ND	ND	2.0/ND	1.0/ND
<i>cis</i> -1,2 DICHLOROETHENE	5.0 ug/l	0.5 ug/l				ND	ND	ND	ND	1.0/ND	0.5/ND
2,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l				ND	ND	ND	ND	ND	ND
BROMOCHLOROMETHANE	5.0 ug/l	0.5 ug/l				ND	ND	ND	ND	ND	ND
1,1,1-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l				2.2/ND	1.7/ND	ND	ND	0.8/ND	0.5/ND
CARBON TETRACHLORIDE	5.0 ug/l	0.5 ug/l				ND	ND	ND	ND	ND	ND
1,1-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l				ND	ND	ND	ND	ND	ND
1,2-DICHLOROETHANE	5.0 ug/l	0.5 ug/l				ND	ND	ND	ND	ND	ND
TRICHLOROETHENE	5.0 ug/l	0.5 ug/l				3.9/ND	3.0/ND	ND	ND	1.3/ND	0.7/ND
1,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l				ND	ND	ND	ND	ND	ND
DIBROMOMETHANE	5.0 ug/l	0.5 ug/l				ND	ND	ND	ND	ND	ND
TRANS-1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	
<i>cis</i> -1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	
1,1,2-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	
TETRACHLOROETHENE	5.0 ug/l	0.5 ug/l			3.3/ND	1.6/ND	ND	ND	ND	ND	

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 3-2 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077 <sup>(24)</sup>		WELL NO. 4-3 N-6076 <sup>(8)</sup>		WELL NO. 5-1 N-6956 <sup>(28)</sup>		
			MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	
<b>VOLATILE ORGANICS (CONT'D.)</b>			<b>OUT OF SERVICE</b>		ND	ND	ND	ND	ND	ND	
1,3-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
CHLOROBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
1,1,1,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
BROMOBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
1,1,2,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
1,2,3-TRICHLOROPROPANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
2-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
4-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
1,2-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
1,3-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
1,4-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
1,2,4-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
HEXACHLOROBUTADIENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
1,2,3-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
BENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
TOLUENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
ETHYLBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
M,P-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND		
O-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND		
STYRENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND		
ISOPROPYLBENZENE (CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND		
N-PROPYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND		
1,3,5-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND		

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 3-2 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077 <sup>(24)</sup>		WELL NO. 4-3 N-6076 <sup>(8)</sup>		WELL NO. 5-1 N-6956 <sup>(28)</sup>	
			MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)
<b><u>VOLATILE ORGANICS (CONT'D.)</u></b>										
TERT-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	OUT OF SERVICE		ND	ND	ND	ND	ND	ND
1,2,4-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
SEC-BUTYLBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
4-ISOPROPYLTOLUENE (P-CUMENE)	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
N-BUTYLBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
METHYL TERT.BUTYL ETHER (MTBE)	10.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 3-2 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421 <sup>(13)</sup>		WELL NO. 5-3 N-8054 <sup>(3)</sup>		WELL NO. 5-4 N-8595		WELL NO. 7-1 <sup>(26)</sup>	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)
<b><u>VOLATILE ORGANICS</u></b>										
DICHLORODIFLUOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	<b>OUT OF SERVICE</b>		ND	ND
CHLOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
VINYL CHLORIDE	2.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
BROMOMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
CHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
TRICHLOROFLUOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,1-DICHLOROETHENE	5.0 ug/l	0.5 ug/l	1.4/ND	0.8/ND	ND	ND			1.2/ND	0.8/ND
METHYLENE CHLORIDE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
TRANS-1,2-DICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,1-DICHLOROETHANE	5.0 ug/l	0.5 ug/l	4.0/ND	2.3/ND	2.0/ND	1.0/ND			ND	ND
<i>cis</i> -1,2 DICHLOROETHENE	5.0 ug/l	0.5 ug/l	1.0/ND	0.1/ND	1.0/ND	0.5/ND			2.0/ND	1.2/ND
2,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
BROMOCHLOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,1,1-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l	2.4/ND	1.5/ND	0.8/ND	0.4/ND			1.8/ND	1.3/ND
CARBON TETRACHLORIDE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,1-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,2-DICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
TRICHLOROETHENE	5.0 ug/l	0.5 ug/l	2.1/ND	1.3/ND	1.3/ND	0.7/ND			***82.5/ND	***57.9/ND
1,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	1.2/ND	0.4/ND	ND	ND			ND	ND
DIBROMOMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
TRANS-1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
<i>cis</i> -1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,1,2-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
TETRACHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			***19.9/ND	***11.8/ND

CONT. - CONTAMINANT

ND - NOT DETECTED

\*\*\* - EXCEEDS NEW YORK STATE/USEPA LIMITS FOR POTABLE WATER

WELL NO. 5-4 OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421 <sup>(13)</sup>		WELL NO. 5-3 N-8054 <sup>(3)</sup>		WELL NO. 5-4 N-8595		WELL NO. 7-1 <sup>(26)</sup>	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)
<b><u>VOLATILE ORGANICS (CONT'D.)</u></b>										
1,3-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
CHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,1,1,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
BROMOBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,1,1,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,2,3-TRICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
2-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
4-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,2-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,3-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,4-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,2,4-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
HEXACHLOROBUTADIENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,2,3-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
BENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
TOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
ETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
M,P-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
O-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
STYRENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
ISOPROPYLBENZENE (CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
N-PROPYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,3,5-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 5-4 OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT  
2007 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421 <sup>(13)</sup>		WELL NO. 5-3 N-8054 <sup>(3)</sup>		WELL NO. 5-4 N-8595		WELL NO. 7-1 <sup>(26)</sup>	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)
<b><u>VOLATILE ORGANICS (CONT'D.)</u></b>										
TERT-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
1,2,4-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
SEC-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
4-ISOPROPYLTOLUENE (P-CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
N-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
METHYL TERT.BUTYL ETHER (MTBE)	10.0 ug/l	0.5 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 5-4 OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR