

PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA

PARAMETERS (mg/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095 ⁽¹⁾		WELL NO. 1-2 N-4096 ⁽³⁾		WELL NO. 2-1 N-7526 ⁽²⁾		WELL NO. 3-1 N-4097	
			MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT
INORGANIC										
ARSENIC	10.0 ug/l	3.0 ug/l	ND	ND	ND	ND	ND	ND	ND	OUT OF SERVICE
BARIUM	2.0 mg/l	0.2 mg/l	ND	ND	ND	ND	ND	ND	ND	
CADMIUM	5.0 ug/l	5.0 ug/l	ND	ND	ND	ND	ND	ND	ND	
CHROMIUM	0.10 mg/l	0.01 mg/l	ND	ND	ND	ND	ND	ND	ND	
COPPER	[1.3] mg/l	0.02 mg/l	ND	ND	ND	ND	ND	ND	ND	
FLUORIDE	2.2 mg/l	0.1 mg/l	ND	ND	ND	ND	ND	ND	ND	
LEAD	[15.0] ug/l	1.0 ug/l	ND	ND	1.1	1.1	ND	ND	ND	
MERCURY	2.0 ug/l	0.2 ug/l	ND	ND	ND	ND	ND	ND	ND	
LANGLIER SATURATION INDEX	None	None	-3.81	-3.81	-5.68/-2.29	-5.57/-2.29	-5.26/-3.69	-5.26/-3.69		
SELENIUM	50 ug/l	5.0 ug/l	ND	ND	ND	ND	ND	ND	ND	
SILVER	0.1 mg/l	0.01 mg/l	ND	ND	ND	ND	ND	ND	ND	
SODIUM	**20/270 mg/l	0.2 mg/l	4.4	4.4	8.1/7.9	7.9/7.9	4.5/4.5	4.5/4.5		
ZINC	5.0 mg/l	0.02 mg/l	ND	ND	0.02	0.02	ND	ND	ND	
COLOR	15 Units	5 Units	ND	ND	ND	ND	ND	ND	ND	
TURBIDITY	5 Units	1 Unit	ND	ND	ND	ND	ND	ND	ND	
ODOR	3 Units	0 Units	ND	ND	ND	ND	ND	ND	ND	
IRON	0.3 mg/l	0.02 mg/l	0.02	0.02	ND	ND	0.02/ND	0.02/ND		
MANGANESE	0.3 mg/l	0.01 mg/l	ND	ND	0.01	0.01	ND	ND	ND	
AMMONIA	None	0.1 mg/l	ND	ND	ND	ND	ND	ND	ND	
NITRITE	1.0 mg/l	0.1 mg/l	ND	ND	ND	ND	ND	ND	ND	
NITRATE	10.0 mg/l	0.1 mg/l	3.3	3.3	6.3 ⁽⁴⁾ /4.8 ⁽²⁾	6.0/4.7	3.3 ⁽⁵⁾ /3.3	2.8/3.3		
CHLORIDE	250 mg/l	1.0 mg/l	6.9	6.9	11.4/4.9	11.1/4.9	6.6/6.8	6.6/6.8		
TOTAL HARDNESS	None	1.0 mg/l	13.1	13.1	21.0/21.5	20.2/21.5	11.0/13.9	11.0/13.9		
TOTAL ALKALINITY	None	0 mg/l	3.6	3.6	1.1/14.0	1.1/14.0	1.8/4.4	1.8/4.4		
pH (BEFORE TREATMENT)	None	None	6.5	6.5	5.3/7.3	5.2/7.3	5.5/8.5	5.5/8.5		
TOTAL DISSOLVED SOLIDS	None	5.0 mg/l	31.0	31.0	86.0/51.0	66.5/51.0	45.0/46.0	45.0/46.0		
DETERGENTS (MBAS)	None	0.08 mg/l	ND	ND	ND	ND	ND	ND	ND	
SULFATE	250 mg/l	5.0 mg/l	ND	ND	ND	ND	ND	ND	ND	
FREE CYANIDE	200 ug/l	10.0 ug/l	ND	ND	ND	ND	ND	ND	ND	
ANTIMONY	6.0 ug/l	5.9 ug/l	ND	ND	ND	ND	ND	ND	ND	
BERYLLIUM	4.0 ug/l	3.0 ug/l	ND	ND	ND	ND	ND	ND	ND	
CALCIUM	None	1.0 mg/l	3.9	3.9	5.3/5.4	5.1/5.4	2.9/4.0	2.9/4.0		
MAGNESIUM	None	1.0 mg/l	0.9	0.9	1.9/1.9	1.8/1.9	0.9/1.0	0.9/1.0		
NICKEL	0.10 mg/l	0.04 mg/l	ND	ND	ND	ND	ND	ND	ND	
THALLIUM	2.0 ug/l	1.9 ug/l	ND	ND	ND	ND	ND	ND	ND	
PERCHLORATE	18 ug/l	1.0 ug/l	1.9	1.9	2.3/ND	2.3/ND	2.3 ⁽²⁾ /ND	2.2/ND		

CONT. - CONTAMINANT

ND - NOT DETECTED

** - 20 mg/l IS THE LIMIT FOR PEOPLE ON HIGHLY RESTRICTED SODIUM DIETS AND 270 mg/l FOR THOSE ON MODERATELY RESTRICTED SODIUM DIETS

*** - EXCEEDS NEW YORK STATE/USEPA LIMITS FOR POTABLE WATER

[] - USEPA/NYS/DH ACTION LEVEL

WELL NO. 3-1 - OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA (continued)**

PARAMETERS (mg/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077 ⁽²⁾		WELL NO. 4-3 N-6076 ⁽¹⁾		WELL NO. 5-1 N-6956 ⁽²⁾		
			MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	
INORGANIC			OUT OF SERVICE		ND	ND	ND	ND	ND	ND	
ARSENIC	10.0 ug/l	3.0 ug/l			ND	ND	ND	ND	ND	ND	ND
BARIUM	2.0 mg/l	0.2 mg/l			ND	ND	ND	ND	ND	ND	ND
CADMIUM	5.0 ug/l	5.0 ug/l			ND	ND	ND	ND	ND	ND	ND
CHROMIUM	0.10 mg/l	0.01 mg/l			ND	ND	ND	ND	ND	ND	ND
COPPER	[1.3] mg/l	0.02 mg/l			0.3/0.3	0.3/0.3	ND	ND	0.03/0.08	0.03/0.08	0.03/0.08
FLUORIDE	2.2 mg/l	0.1 mg/l			ND	ND	ND	ND	ND	ND	ND
LEAD	[15.0] ug/l	1.0 ug/l			ND	ND	ND	ND	2.8/6.1	2.8/6.1	2.8/6.1
MERCURY	2.0 ug/l	0.2 ug/l			ND	ND	ND	ND	ND	ND	ND
LANGLIER SATURATION INDEX	None	None			-4.28/-2.79	-4.28/-2.79	-4.98	-4.98	-6.26/-4.46	-6.26/-4.46	-6.26/-4.46
SELENIUM	50 ug/l	5.0 ug/l			ND	ND	ND	ND	ND	ND	ND
SILVER	0.1 mg/l	0.01 mg/l			ND	ND	ND	ND	ND	ND	ND
SODIUM	**20/270 mg/l	0.2 mg/l			13.0/12.6	13.0/12.6	6.1	6.1	6.5/6.7	6.5/6.7	6.5/6.7
ZINC	5.0 mg/l	0.02 mg/l			ND	ND	ND	ND	ND	ND	ND
COLOR	15 Units	5 Units			ND	ND	ND	ND	ND	ND	ND
TURBIDITY	5 Units	1 Unit			ND	ND	ND	ND	ND	ND	ND
ODOR	3 Units	0 Units			ND	ND	ND	ND	ND	ND	ND
IRON	0.3 mg/l	0.02 mg/l			0.02/0.05	0.02/0.05	ND	ND	ND	ND	ND
MANGANESE	0.3 mg/l	0.01 mg/l			0.01/0.01	0.01/0.01	ND	ND	ND	ND	ND
AMMONIA	None	0.1 mg/l			ND	ND	ND	ND	ND	ND	ND
NITRITE	1.0 mg/l	0.1 mg/l			ND	ND	ND	ND	ND	ND	ND
NITRATE	10.0 mg/l	0.1 mg/l			12.0 ⁽¹¹⁾ /10.6	9.7/10.6	4.5 ⁽¹²⁾	4.0	3.8 ⁽¹²⁾ /3.8	3.2/3.8	3.2/3.8
CHLORIDE	250 mg/l	1.0 mg/l			20.1/19.7	20.1/19.7	8.4	8.4	10.3/12.6	10.3/12.6	10.3/12.6
TOTAL HARDNESS	None	1.0 mg/l			43.0/43.2	43.0/43.2	14.4	14.4	13.3/14.8	13.3/14.8	13.3/14.8
TOTAL ALKALINITY	None	0 mg/l			4.4/5.2	4.4/5.2	2.0	2.0	1.4/ND	1.4/ND	1.4/ND
pH (BEFORE TREATMENT)	None	None			5.5/6.9	5.5/6.9	5.6	5.6	4.7/6.3	4.7/6.3	4.7/6.3
TOTAL DISSOLVED SOLIDS	None	5.0 mg/l			119.0/118.0	119.0/118.0	42.0	42.0	39.0/44.0	39.0/44.0	39.0/44.0
DETERGENTS (MBAS)	None	0.08 mg/l	ND	ND	ND	ND	ND	ND	ND		
SULFATE	250 mg/l	5.0 mg/l	ND	ND	ND	ND	ND	ND	ND		
FREE CYANIDE	200 ug/l	10.0 ug/l	ND	ND	ND	ND	ND	ND	ND		
ANTIMONY	6.0 ug/l	5.9 ug/l	ND	ND	ND	ND	ND	ND	ND		
BERYLLIUM	4.0 ug/l	3.0 ug/l	ND	ND	ND	ND	ND	ND	ND		
CALCIUM	None	1.0 mg/l	11.6/11.9	11.6/11.9	3.8	3.8	3.2/3.6	3.2/3.6	3.2/3.6		
MAGNESIUM	None	1.0 mg/l	3.4/3.3	3.4/3.3	1.2	1.2	1.3/1.5	1.3/1.5	1.3/1.5		
NICKEL	0.10 mg/l	0.04 mg/l	ND	ND	ND	ND	ND	ND	ND		
THALLIUM	2.0 ug/l	1.9 ug/l	ND	ND	ND	ND	ND	ND	ND		
PERCHLORATE	18 ug/l	1.0 ug/l	7.1 ⁽⁴⁾	6.7	4.7 ⁽⁴⁾	4.3	3.7 ⁽⁵⁾ /3.0	3.7/3.0	3.7/3.0		

ND - NOT DETECTED

Note: Well 4-2 is blended with low nitrate Well 4-3 to provide water with nitrate levels below 10 ppm.

*** - EXCEEDS NEW YORK STATE/USEPA LIMITS FOR POTABLE WATER

** - 20 mg/l IS THE LIMIT FOR PEOPLE ON HIGHLY RESTRICTED SODIUM DIETS AND 270 mg/l FOR THOSE ON MODERATELY RESTRICTED SODIUM DIETS

[] - USEPA/NYS/SDH ACTION LEVEL

WELL NO. 3-2 - OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA (continued)**

PARAMETERS (mg/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421 ⁽²⁾		WELL NO. 5-3 N-7421 ⁽²⁾		WELL NO. 5-4 N-8595 ⁽¹⁾		WELL NO. 7-1 ⁽²⁾	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)
INORGANIC										
ARSENIC	10.0 ug/l	3.0 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
BARIUM	2.0 mg/l	0.2 mg/l	ND	ND	ND	ND			ND	ND
CADMIUM	5.0 ug/l	5.0 ug/l	ND	ND	ND	ND			ND	ND
CHROMIUM	0.10 mg/l	0.01 mg/l	ND	ND	ND	ND			ND	ND
COPPER	[1.3] mg/l	0.02 mg/l	0.04/0.08	0.04/0.08	0.2/0.1	0.2/0.1			ND	ND
FLUORIDE	2.2 mg/l	0.1 mg/l	ND	ND	ND	ND			ND	ND
LEAD	[15.0] ug/l	1.0 ug/l	1.3/6.1	1.3/6.1	1.4/6.1	1.4/6.1			1.1/ND	1.1/ND
MERCURY	2.0 ug/l	0.2 ug/l	ND	ND	ND	ND			ND	ND
LANGLIER SATURATION INDEX	None	None	-6.97/-4.46	-6.97/-4.46	-5.47/-4.46	-5.47/-4.46			-6.45/-4.52	-6.45/-4.52
SELENIUM	50 ug/l	5.0 ug/l	ND	ND	ND	ND			ND	ND
SILVER	0.1 mg/l	0.01 mg/l	ND	ND	ND	ND			ND	ND
SODIUM	**20/270 mg/l	0.2 mg/l	11.6/6.7	11.6/6.7	7.3/6.7	7.3/6.7			2.6/2.7	2.6/2.7
ZINC	5.0 mg/l	0.02 mg/l	0.02	0.02	0.03	0.03			ND	ND
COLOR	15 Units	5 Units	ND	ND	ND	ND			ND	ND
TURBIDITY	5 Units	1 Unit	ND	ND	ND	ND			ND	ND
ODOR	3 Units	0 Units	ND	ND	ND	ND			ND	ND
IRON	0.3 mg/l	0.02 mg/l	ND	ND	ND	ND			0.2/ND	0.2/ND
MANGANESE	0.3 mg/l	0.01 mg/l	0.01	0.01	ND	ND			0.02/ND	0.02/ND
AMMONIA	None	0.1 mg/l	ND	ND	ND	ND			ND	ND
NITRITE	1.0 mg/l	0.1 mg/l	ND	ND	ND	ND			ND	ND
NITRATE	10.0 mg/l	0.1 mg/l	8.8 ⁽¹²⁾ /3.8	7.5/3.8	4.3 ⁽⁷⁾ /3.8	3.8/3.8			0.4 ⁽⁵⁾ /0.4	0.3/0.4
CHLORIDE	250 mg/l	1.0 mg/l	17.7/12.6	17.7/12.6	14.4/12.6	14.4/12.6			3.9/4.9	3.9/4.9
TOTAL HARDNESS	None	1.0 mg/l	32.4/14.8	32.4/14.8	16.5/14.8	16.5/14.8			3.5/4.4	3.5/4.4
TOTAL ALKALINITY	None	0 mg/l	1.4	1.4	1.6/1.4	1.6/1.4			2.0/2.4	2.0/2.4
pH (BEFORE TREATMENT)	None	None	4.9/6.3	4.9/6.3	5.2/6.3	5.2/6.3			4.8/6.5	4.8/6.5
TOTAL DISSOLVED SOLIDS	None	5.0 mg/l	90.0/44.0	90.0/44.0	52.0/44.0	52.0/44.0			13.0/22.0	130/22.0
DETERGENTS (MBAS)	None	0.08 mg/l	ND	ND	ND	ND			ND	ND
SULFATE	250 mg/l	5.0 mg/l	5.0	5.0	ND	ND			ND	ND
FREE CYANIDE	200 ug/l	10.0 ug/l	ND	ND	ND	ND			ND	ND
ANTIMONY	6.0 ug/l	5.9 ug/l	ND	ND	ND	ND			ND	ND
BERYLLIUM	4.0 ug/l	3.0 ug/l	ND	ND	ND	ND			ND	ND
CALCIUM	None	1.0 mg/l	7.8/3.6	7.8/3.6	4.0/3.6	4.0/3.6			0.8/1.2	0.8/1.2
MAGNESIUM	None	1.0 mg/l	3.1/1.5	3.1/1.5	1.6/1.5	1.6/1.5			0.4/0.4	0.4/0.4
NICKEL	0.10 mg/l	0.04 mg/l	ND	ND	ND	ND			ND	ND
THALLIUM	2.0 ug/l	1.9 ug/l	ND	ND	ND	ND			ND	ND
PERCHLORATE	18 ug/l	1.0 ug/l	13.2 ⁽⁴⁾ /3.0	10.3/3.0	6.1 ⁽³⁾ /3.0	3.7/3.0			ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

** - 20 mg/l IS THE LIMIT FOR PEOPLE ON HIGHLY RESTRICTED SODIUM DIETS AND 270 mg/l FOR THOSE ON MODERATELY RESTRICTED SODIUM DIETS

[] - USEPA/NYS DH ACTION LEVEL

WELL NO. 1-1 NOT IN USE DURING 2008

WELL NO. 5-4 - OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095 ⁽¹⁾		WELL NO. 1-2 N-4096 ⁽¹⁾		WELL NO. 2-1 N-7526 ⁽¹⁾		WELL NO. 3-1 N-4097	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
SYNTHETIC ORGANICS CONTAMINANTS										
(SOC)										
LINDANE	0.2 ug/l	0.025 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
HEPTACHLOR	0.4 ug/l	0.025 ug/l	ND	ND	ND	ND	ND	ND		
ALDRIN	5.0 ug/l	0.025 ug/l	ND	ND	ND	ND	ND	ND		
HEPTACHLOR EPOXIDE	0.2 ug/l	0.025 ug/l	ND	ND	ND	ND	ND	ND		
DIELDRIN	2.0 ug/l	0.05 ug/l	ND	ND	ND	ND	ND	ND		
ENDRIN	2.0 ug/l	0.05 ug/l	ND	ND	ND	ND	ND	ND		
METHOXYCHLOR	40.0 ug/l	0.25 ug/l	ND	ND	ND	ND	ND	ND		
TOXAPHENE	3.0 ug/l	2.5 ug/l	ND	ND	ND	ND	ND	ND		
CHLORDANE	2.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
TOTAL PCBs	0.5 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
PROPACHLOR	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND		
ALACHLOR	2.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND		
SIMAZINE	4.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
ATRAZINE	3.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
METOLACHLOR	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND		
METRIBUZIN	50.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
BUTACHLOR	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND		

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 3-1 - OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077 ⁽¹⁾		WELL NO. 4-3 N-6076 ⁽¹⁾		WELL NO. 5-1 N-6956 ⁽¹⁾	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<u>SYNTHETIC ORGANICS CONTAMINANTS</u>										
<u>(SOC)</u>										
LINDANE	0.2 ug/l	0.025 ug/l	OUT OF SERVICE		ND	ND	ND	ND	ND	ND
HEPTACHLOR	0.4 ug/l	0.025 ug/l		ND	ND	ND	ND	ND	ND	ND
ALDRIN	5.0 ug/l	0.025 ug/l		ND	ND	ND	ND	ND	ND	ND
HEPTACHLOR EPOXIDE	0.2 ug/l	0.025 ug/l		ND	ND	ND	ND	ND	ND	ND
DIELDRIN	2.0 ug/l	0.05 ug/l		ND	ND	ND	ND	ND	ND	ND
ENDRIN	2.0 ug/l	0.05 ug/l		ND	ND	ND	ND	ND	ND	ND
METHOXYCHLOR	40.0 ug/l	0.25 ug/l		ND	ND	ND	ND	ND	ND	ND
TOXAPHENE	3.0 ug/l	2.5 ug/l		ND	ND	ND	ND	ND	ND	ND
CHLORDANE	2.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND
TOTAL PCBs	0.5 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND
PROPACHLOR	50.0 ug/l	1.0 ug/l		ND	ND	ND	ND	ND	ND	ND
ALACHLOR	2.0 ug/l	1.0 ug/l		ND	ND	ND	ND	ND	ND	ND
SIMAZINE	4.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND
ATRAZINE	3.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND
METOLACHLOR	50.0 ug/l	1.0 ug/l		ND	ND	ND	ND	ND	ND	ND
METRIBUZIN	50.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
BUTACHLOR	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL 3-2 - OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421 ⁽¹⁾		WELL NO. 5-3 N-8054 ⁽¹⁾		WELL NO. 5-4 N-8595		WELL NO. 7-1 ⁽¹⁾	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<u>SYNTHETIC ORGANICS CONTAMINANTS</u>										
<u>(SOC)</u>										
LINDANE	0.2 ug/l	0.025 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
HEPTACHLOR	0.4 ug/l	0.025 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
ALDRIN	5.0 ug/l	0.025 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
HEPTACHLOR EPOXIDE	0.2 ug/l	0.025 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
DIELDRIN	2.0 ug/l	0.05 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
ENDRIN	2.0 ug/l	0.05 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
METHOXYCHLOR	40.0 ug/l	0.25 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
TOXAPHENE	3.0 ug/l	2.5 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
CHLORDANE	2.0 ug/l	0.5 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
TOTAL PCBs	0.5 ug/l	0.5 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
PROPACHLOR	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
ALACHLOR	2.0 ug/l	1.0 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
SIMAZINE	4.0 ug/l	0.5 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
ATRAZINE	3.0 ug/l	0.5 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
METOLACHLOR	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
METRIBUZIN	50.0 ug/l	0.5 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
BUTACHLOR	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 5-4 - OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095 ⁽¹⁾		WELL NO. 1-2 N-409 ⁽¹⁾		WELL NO. 2-1 N-7526 ⁽¹⁾		WELL NO. 3-1 N-4097	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
SYNTHETIC ORGANICS CONTAMINANTS (SOC)										
(CONT'D.)										
2,4-D	50.0 ug/l	0.25 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
2,4,5-TP (SILVEX)	10.0 ug/l	0.13 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
DINOSEB	7.0 ug/l	0.2 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
DALAPON	200 ug/l	0.7 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
PICLORAM	500 ug/l	0.6 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
DICAMBA	50.0 ug/l	0.08 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
PENTACHLOROPHENOL	1.0 ug/l	0.2 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
HEXACHLOROCYCLOPENTADIENE	50.0 ug/l	0.64 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
bis(2-ETHYLHEXYL)ADIPATE	400 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
bis(2-ETHYLHEXYL)PHTHALATE	6.0 ug/l	3.0 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
HEXACHLOROBENZENE	1.0 ug/l	0.25 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
BENZO(A)PYRENE	0.2 ug/l	0.1 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
ALDICARB SULFONE	2.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
ALDICARBSULFOXIDE	4.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
ALDICARB	3.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
TOTAL ALDICARBS	7.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
OXAMYL	200 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
METHOMYL	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
3-HYDROXYCARBOFURAN	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
CARBOFURAN	40.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
CARBARYL	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
GLYPHOSATE	700 ug/l	10.0 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
DIQUAT	20 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
ENDOTHALL	100 ug/l	50.0 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
1,2-DIBROMOETHANE (EDB)	0.05 ug/l	0.02 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
1,2-DIBROMO-3-CHLOROPROPANE	0.2 ug/l	0.02 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	
DIOXIN	30 Pg/L	5.0 Pg/L	ND	ND	ND	ND	ND	ND	OUT OF SERVICE	

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 3-1 - OUT OF SERVICE

Pg/L - PICOGRAMS PER LITER

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077 ⁽¹⁾		WELL NO. 4-3 N-6076 ⁽¹⁾		WELL NO. 5-1 N-6956 ⁽¹⁾	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
SYNTHETIC ORGANICS CONTAMINANTS (SOC)										
(CONT'D.)										
2,4-D	50.0 ug/l	0.25 ug/l	OUT OF SERVICE		ND	ND	ND	ND	ND	ND
2,4,5-TP (SILVEX)	10.0 ug/l	0.13 ug/l		ND	ND	ND	ND	ND	ND	ND
DINOSEB	7.0 ug/l	0.2 ug/l		ND	ND	ND	ND	ND	ND	ND
DALAPON	200 ug/l	0.7 ug/l		ND	ND	ND	ND	ND	ND	ND
PICLORAM	500 ug/l	0.6 ug/l		ND	ND	ND	ND	ND	ND	ND
DICAMBA	50.0 ug/l	0.08 ug/l		ND	ND	ND	ND	ND	ND	ND
PENTACHLOROPHENOL	1.0 ug/l	0.2 ug/l		ND	ND	ND	ND	ND	ND	ND
HEXACHLOROCYCLOPENTADIENE	50.0 ug/l	0.64 ug/l		ND	ND	ND	ND	ND	ND	ND
bis(2-ETHYLHEXYL)ADIPATE	400 ug/l	1.0 ug/l		ND	ND	ND	ND	ND	ND	ND
bis(2-ETHYLHEXYL)PHTHALATE	6.0 ug/l	3.0 ug/l		ND	ND	ND	ND	ND	ND	ND
HEXACHLOROBENZENE	1.0 ug/l	0.25 ug/l		ND	ND	ND	ND	ND	ND	ND
BENZO(A)PYRENE	0.2 ug/l	0.1 ug/l		ND	ND	ND	ND	ND	ND	ND
ALDICARB SULFONE	2.0 ug/l	1.0 ug/l		ND	ND	ND	ND	ND	ND	ND
ALDICARBSULFOXIDE	4.0 ug/l	1.0 ug/l		ND	ND	ND	ND	ND	ND	ND
ALDICARB	3.0 ug/l	1.0 ug/l		ND	ND	ND	ND	ND	ND	ND
TOTAL ALDICARBS	7.0 ug/l	1.0 ug/l		ND	ND	ND	ND	ND	ND	ND
OXAMYL	200 ug/l	1.0 ug/l		ND	ND	ND	ND	ND	ND	ND
METHOMYL	50.0 ug/l	1.0 ug/l		ND	ND	ND	ND	ND	ND	ND
3-HYDROXYCARBOFURAN	50.0 ug/l	1.0 ug/l		ND	ND	ND	ND	ND	ND	ND
CARBOFURAN	40.0 ug/l	1.0 ug/l		ND	ND	ND	ND	ND	ND	ND
CARBARYL	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	
GLYPHOSATE	700 ug/l	10.0 ug/l	ND	ND	ND	ND	ND	ND	ND	
DIQUAT	20 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	
ENDOTHALL	100 ug/l	50.0 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,2-DIBROMOETHANE (EDB)	0.05 ug/l	0.02 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,2-DIBROMO-3-CHLOROPROPANE	0.2 ug/l	0.02 ug/l	ND	ND	ND	ND	ND	ND	ND	
DIOXIN	30 Pg/L	5.0 Pg/L	ND	ND	ND	ND	ND	ND	ND	

CONT. - CONTAMINANT

ND - NOT DETECTED

Pg/L - PICOGRAMS PER LITER

WELL NO. 3-2 - OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421 ⁽¹⁾		WELL NO. 5-3 N-8054 ⁽¹⁾		WELL NO. 5-4 N-8595		WELL NO. 7-1 ⁽¹⁾	
			MAX. RESULT	AVG. RESULT	ND RESULT	ND RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<u>SYNTHETIC ORGANICS CONTAMINANTS (SOC)</u>										
<u>(CONT'D.)</u>										
2,4-D	50.0 ug/l	0.25 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
2,4,5-TP (SILVEX)	10.0 ug/l	0.13 ug/l	ND	ND	ND	ND			ND	ND
DINOSEB	7.0 ug/l	0.2 ug/l	ND	ND	ND	ND			ND	ND
DALAPON	200 ug/l	0.7 ug/l	ND	ND	ND	ND			ND	ND
PICLORAM	500 ug/l	0.6 ug/l	ND	ND	ND	ND			ND	ND
DICAMBA	50.0 ug/l	0.08 ug/l	ND	ND	ND	ND			ND	ND
PENTACHLOROPHENOL	1.0 ug/l	0.2 ug/l	ND	ND	ND	ND			ND	ND
HEXACHLOROCYCLOPENTADIENE	50.0 ug/l	0.64 ug/l	ND	ND	ND	ND			ND	ND
bis(2-ETHYLHEXYL)ADIPATE	400 ug/l	1.0 ug/l	ND	ND	ND	ND			ND	ND
bis(2-ETHYLHEXYL)PHTHALATE	6.0 ug/l	3.0 ug/l	ND	ND	ND	ND			ND	ND
HEXACHLOROBENZENE	1.0 ug/l	0.25 ug/l	ND	ND	ND	ND			ND	ND
BENZO(A)PYRENE	0.2 ug/l	0.1 ug/l	ND	ND	ND	ND			ND	ND
ALDICARB SULFONE	2.0 ug/l	1.0 ug/l	ND	ND	ND	ND			ND	ND
ALDICARBSULFOXIDE	4.0 ug/l	1.0 ug/l	ND	ND	ND	ND			ND	ND
ALDICARB	3.0 ug/l	1.0 ug/l	ND	ND	ND	ND			ND	ND
TOTAL ALDICARBS	7.0 ug/l	1.0 ug/l	ND	ND	ND	ND			ND	ND
OXAMYL	200 ug/l	1.0 ug/l	ND	ND	ND	ND			ND	ND
METHOMYL	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND			ND	ND
3-HYDROXYCARBOFURAN	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND			ND	ND
CARBOFURAN	40.0 ug/l	1.0 ug/l	ND	ND	ND	ND			ND	ND
CARBARYL	50.0 ug/l	1.0 ug/l	ND	ND	ND	ND			ND	ND
GLYPHOSATE	700 ug/l	10.0 ug/l	ND	ND	ND	ND			ND	ND
DIQUAT	20 ug/l	1.0 ug/l	ND	ND	ND	ND			ND	ND
ENDOTHALL	100 ug/l	50.0 ug/l	ND	ND	ND	ND			ND	ND
1,2-DIBROMOETHANE (EDB)	0.05 ug/l	0.02 ug/l	ND	ND	ND	ND			ND	ND
1,2-DIBROMO-3-CHLOROPROPANE	0.2 ug/l	0.02 ug/l	ND	ND	ND	ND			ND	ND
DIOXIN	30 Pg/L	5.0 Pg/L	ND	ND	ND	ND			ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

Pg/L - PICOGRAMS PER LITER

WELL NO. 5-4 - OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095 ⁽³⁾		WELL NO. 1-2 N-409 ⁽⁹⁾		WELL NO. 2-1 N-7526 ⁽²⁵⁾		WELL NO. 3-1 N-4097	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<u>TRIHALOMETHANES AND HALOACETIC ACIDS</u>										
CHLOROACETIC ACID	---	< 2.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	
BROMOACETIC ACID	---	< 1.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	
DICHLOROACETIC ACID	---	< 1.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	
TRICHLOROACETIC ACID	---	< 1.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	
DIBROMOACETIC ACID	---	< 2.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	
TOTAL HALOACETIC ACID	60 ug/l	< 2.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	
CHLOROFORM	50 ug/l	< 0.5 ug/l	0.7	0.2	0.5/ND	0.3/ND	2.2/ND	1.1/ND	OUT OF SERVICE	
BROMODICHLOROMETHANE	50 ug/l	< 0.5 ug/l	1.9	0.6	ND	ND	ND	ND	OUT OF SERVICE	
DIBROMOCHLOROMETHANE	50 ug/l	< 0.5 ug/l	3.6	1.2	ND	ND	2.9/ND	0.2/ND	OUT OF SERVICE	
BROMOFORM	50 ug/l	< 0.5 ug/l	3.4	1.1	ND	ND	ND	ND	OUT OF SERVICE	
TOTAL TRIHALOMETHANES	80 ug/l	< 1.0 ug/l	9.6	3.1	0.5/ND	0.3/ND	5.1/ND	1.3/ND	OUT OF SERVICE	
<u>RADIONUCLIDES</u>										
GROSS ALPHA	15 pCi/L	< 3 pCi/L	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	
GROSS BETA	50 pCi/L	< 3 pCi/L	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	
RADIUM 228	---	< 3 pCi/L	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	

CONT. - CONTAMINANT

ND - NOT DETECTED

pCi/L - pico Curies per Liter

WELL NO. 3-1 - OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077 ⁽²⁴⁾		WELL NO. 4-3 N-6076 ⁽⁵⁾		WELL NO. 5-1 N-6956 ⁽²⁵⁾		
			MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)	MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)	MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)	
<u>TRIALOMETHANES AND HALOACETIC ACIDS</u>											
CHLOROACETIC ACID	---	< 2.0 ug/l	OUT OF SERVICE	SERVICE	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
BROMOACETIC ACID	---	< 1.0 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED
DICHLOROACETIC ACID	---	< 1.0 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED
TRICHLOROACETIC ACID	---	< 1.0 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED
DIBROMOACETIC ACID	---	< 2.0 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED
TOTAL HALOACETIC ACID	60 ug/l	< 2.0 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED
CHLOROFORM	50 ug/l	< 0.5 ug/l			0.8/ND	0.4/ND	ND	ND	0.9/ND	0.5/ND	0.5/ND
BROMODICHLOROMETHANE	50 ug/l	< 0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
DIBROMOCHLOROMETHANE	50 ug/l	< 0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
BROMOFORM	50 ug/l	< 0.5 ug/l			ND	ND	ND	ND	ND	ND	ND
TOTAL TRIHALOMETHANES	80 ug/l	< 1.0 ug/l	0.8/ND	0.4/ND	ND	ND	0.9/ND	0.5/ND	0.5/ND		
<u>RADIONUCLIDES</u>											
GROSS ALPHA	15 pCi/L	< 3 pCi/L			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
GROSS BETA	50 pCi/L	< 3 pCi/L			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
RADIUM 228	---	< 3 pCi/L			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	

ND - NOT DETECTED

WELL NO. 3-2 - OUT OF SERVICE

pCi/L - pico Curies per Liter

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421 ⁽²³⁾		WELL NO. 5-3 N-8054 ⁽¹⁶⁾		WELL NO. 5-4 N-8595		WELL NO. 7-1 ⁽²⁷⁾	
			MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)	ND RESULT (Raw/Treated)	ND RESULT (Raw/Treated)	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)
<u>TRIALOMETHANES AND HALOACETIC ACIDS</u>										
CHLOROACETIC ACID	---	< 2.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	OUT OF SERVICE	NOT TESTED	NOT TESTED
BROMOACETIC ACID	---	< 1.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	OUT OF SERVICE	NOT TESTED	NOT TESTED
DICHLOROACETIC ACID	---	< 1.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	OUT OF SERVICE	NOT TESTED	NOT TESTED
TRICHLOROACETIC ACID	---	< 1.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	OUT OF SERVICE	NOT TESTED	NOT TESTED
DIBROMOACETIC ACID	---	< 2.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	OUT OF SERVICE	NOT TESTED	NOT TESTED
TOTAL HALOACETIC ACID	60 ug/l	< 2.0 ug/l	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	OUT OF SERVICE	NOT TESTED	NOT TESTED
CHLOROFORM	50 ug/l	< 0.5 ug/l	2.0/ND	1.5/ND	1.9/ND	0.9/ND	OUT OF SERVICE	OUT OF SERVICE	1.6/ND	1.3/ND
BROMODICHLOROMETHANE	50 ug/l	< 0.5 ug/l	ND	ND	0.8/ND	0.1/ND	OUT OF SERVICE	OUT OF SERVICE	ND	ND
DIBROMOCHLOROMETHANE	50 ug/l	< 0.5 ug/l	ND	ND	1.7/ND	0.3/ND	OUT OF SERVICE	OUT OF SERVICE	ND	ND
BROMOFORM	50 ug/l	< 0.5 ug/l	ND	ND	1.2/ND	0.2/ND	OUT OF SERVICE	OUT OF SERVICE	ND	ND
TOTAL TRIHALOMETHANES	80 ug/l	< 1.0 ug/l	2.0/ND	1.5/ND	5.6/ND	1.5/ND	OUT OF SERVICE	OUT OF SERVICE	1.6/ND	1.3/ND
<u>RADIONUCLIDES</u>										
GROSS ALPHA	15 pCi/L	< 3 pCi/L	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	OUT OF SERVICE	NOT TESTED	NOT TESTED
GROSS BETA	50 pCi/L	< 3 pCi/L	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	OUT OF SERVICE	NOT TESTED	NOT TESTED
RADIUM 228	---	< 3 pCi/L	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	OUT OF SERVICE	OUT OF SERVICE	NOT TESTED	NOT TESTED

CONT. - CONTAMINANT

ND - NOT DETECTED

pCi/L - pico Curies per Liter

WELL NO. 5-4 - OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095 ⁽³⁾		WELL NO. 1-2 N-4096 ⁽⁹⁾		WELL NO. 2-1 N-7526 ⁽²⁵⁾		WELL NO. 3-1 N-4097	
			MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)	MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)	MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)	MAX. RESULT	AVG. RESULT
<u>VOLATILE ORGANICS</u>										
DICHLORODIFLUOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	OUT OF SERVICE
CHLOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
VINYL CHLORIDE	2.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
BROMOMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
CHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
TRICHLOROFLUOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,1-DICHLOROETHENE	5.0 ug/l	0.5 ug/l	2.0/ND	0.7/ND	***5.8/ND	2.3/ND	***51.7/ND	***32.3/ND	ND	
METHYLENE CHLORIDE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
TRANS-1,2-DICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,1-DICHLOROETHANE	5.0 ug/l	0.5 ug/l	1.7/ND	0.8/ND	3.4/ND	2.5/ND	3.5/ND	1.9/ND	ND	
<i>cis</i> -1,2 DICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	1.2/ND	0.6/ND	ND	
2,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
BROMOCHLOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,1,1-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l	2.6/ND	1.0/ND	***6.1/ND	2.6/ND	***48.2/ND	***32.9/ND	ND	
CARBON TETRACHLORIDE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,1-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,2-DICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	0.8/ND	0.3/ND	ND	
TRICHLOROETHENE	5.0 ug/l	0.5 ug/l	9.0/ND	0.3/ND	2.0/ND	1.0/ND	***23.0/ND	***12.9/ND	ND	
1,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
DIBROMOMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
TRANS-1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
<i>cis</i> -1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,1,2-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
TETRACHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	1.9/ND	1.3/ND	***7.6/ND	4.7/ND	ND	

CONT. - CONTAMINANT

ND - NOT DETECTED

*** - EXCEEDS NEW YORK STATE/USEPA LIMITS FOR POTABLE WATER

WELL NO. 1-1 - NOT IN SERVICE DURING 2008

WELL NO. 3-1 - OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095 ⁽³⁾		WELL NO. 1-2 N-4096 ⁽⁹⁾		WELL NO. 2-1 N-7526 ⁽²⁵⁾		WELL NO. 3-1 N-4097	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)	MAX. RESULT	AVG. RESULT
<u>VOLATILE ORGANICS (CONT'D.)</u>										
1,3-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	OUT OF SERVICE
CHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,1,1,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
BROMOBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,1,2,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,2,3-TRICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
2-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
4-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,2-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,3-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,4-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,2,4-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
HEXACHLOROBUTADIENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,2,3-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
BENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
TOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
ETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
M,P-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
O-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
STYRENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
ISOPROPYLBENZENE (CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
N-PROPYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
1,3,5-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 1-1 - NOT IN SERVICE DURING 2008

WELL NO. 3-1 - OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1-1 N-4095 ⁽³⁾		WELL NO. 1-2 N-4096 ⁽⁹⁾		WELL NO. 2-1 N-7526 ⁽²⁵⁾		WELL NO. 3-1 N-4097	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)	MAX. RESULT	AVG. RESULT
<u>VOLATILE ORGANICS (CONT'D.)</u>										
TERT-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	OUT OF SERVICE
1,2,4-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
SEC-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
4-ISOPROPYLTOLUENE (P-CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
N-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	
METHYL TERT.BUTYL ETHER (MTBE)	10.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 1-1 - NOT IN SERVICE DURING 2008

WELL NO. 3-1 - OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077 ⁽²⁴⁾		WELL NO. 4-3 N-6076 ⁽⁵⁾		WELL NO. 5-1 N-6956 ⁽²⁵⁾	
			MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)
<u>VOLATILE ORGANICS</u>			OUT OF SERVICE		ND	ND	ND	ND	ND	ND
DICHLORODIFLUOROMETHANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
CHLOROMETHANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
VINYL CHLORIDE	2.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
BROMOMETHANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
CHLOROETHANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
TRICHLOROFLUOROMETHANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
1,1-DICHLOROETHENE	5.0 ug/l	0.5 ug/l			2.7/ND	1.6/ND	ND	ND	0.6/ND	0.2/ND
METHYLENE CHLORIDE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
TRANS-1,2-DICHLOROETHENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
1,1-DICHLOROETHANE	5.0 ug/l	0.5 ug/l			***6.0/ND	3.9/ND	ND	ND	1.7/ND	1.1/ND
<i>cis</i> -1,2 DICHLOROETHENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	0.6/ND	0.2/ND
2,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
BROMOCHLOROMETHANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
1,1,1-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l			2.6/ND	1.7/ND	ND	ND	0.9/ND	0.4/ND
CARBON TETRACHLORIDE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
1,1-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
1,2-DICHLOROETHANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
TRICHLOROETHENE	5.0 ug/l	0.5 ug/l			4.7/ND	3.1/ND	ND	ND	1.1/ND	0.7/ND
1,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
DIBROMOMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
TRANS-1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
<i>cis</i> -1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,1,2-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
TETRACHLOROETHENE	5.0 ug/l	0.5 ug/l	2.6/ND	1.7/ND	ND	ND	ND	ND		

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 3-2 - OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077 ⁽²⁴⁾		WELL NO. 4-3 N-6076 ⁽⁵⁾		WELL NO. 5-1 N-6956 ⁽²⁵⁾	
			MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)
<u>VOLATILE ORGANICS (CONT'D.)</u>			OUT OF SERVICE		ND	ND	ND	ND	ND	ND
1,3-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
CHLOROBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
1,1,1,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
BROMOBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
1,1,2,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
1,2,3-TRICHLOROPROPANE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
2-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
4-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
1,2-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
1,3-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
1,4-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
1,2,4-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
HEXACHLOROBUTADIENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
1,2,3-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
BENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
TOLUENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
ETHYLBENZENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
M,P-XYLENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
O-XYLENE	5.0 ug/l	0.5 ug/l			ND	ND	ND	ND	ND	ND
STYRENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
ISOPROPYLBENZENE (CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
N-PROPYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		
1,3,5-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND		

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 3-2 - OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3-2 N-6580		WELL NO. 4-2 N-6077 ⁽²⁴⁾		WELL NO. 4-3 N-6076 ⁽⁵⁾		WELL NO. 5-1 N-6956 ⁽²⁵⁾	
			MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)
<u>VOLATILE ORGANICS (CONT'D.)</u>										
TERT-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	OUT OF SERVICE		ND	ND	ND	ND	ND	ND
1,2,4-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	
SEC-BUTYLBENZENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	
4-ISOPROPYLTOLUENE (P-CUMENE)	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	
N-BUTYLBENZENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	
METHYL TERT.BUTYL ETHER (MTBE)	10.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 3-2 - OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421 ⁽²³⁾		WELL NO. 5-3 N-8054 ⁽³⁾		WELL NO. 5-4 N-8595		WELL NO. 7-1 ⁽²⁷⁾	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)
<u>VOLATILE ORGANICS</u>										
DICHLORODIFLUOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
CHLOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
VINYL CHLORIDE	2.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
BROMOMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
CHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
TRICHLOROFLUOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,1-DICHLOROETHENE	5.0 ug/l	0.5 ug/l	1.4/ND	0.9/ND	3.1/ND	2.0/ND			1.6/ND	1.4/ND
METHYLENE CHLORIDE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
TRANS-1,2-DICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,1-DICHLOROETHANE	5.0 ug/l	0.5 ug/l	2.9/ND	2.2/ND	***10.3/ND	***7.7/ND			ND	ND
<i>cis</i> -1,2 DICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	***5.3/ND	4.1/ND			2.0/ND	1.5/ND
2,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
BROMOCHLOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,1,1-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l	2.0/ND	1.5/ND	4.8/ND	2.9/ND			2.2/ND	1.8/ND
CARBON TETRACHLORIDE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,1-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,2-DICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
TRICHLOROETHENE	5.0 ug/l	0.5 ug/l	1.7/ND	1.2/ND	3.4/ND	3.0/ND			***99.0/ND	***78.0/ND
1,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	1.1/ND	0.5/ND	0.5/ND	0.1/ND			ND	ND
DIBROMOMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
TRANS-1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
<i>cis</i> -1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,1,2-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
TETRACHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	0.6/ND	0.1/ND			***23.8/ND	***18.3/ND

CONT. - CONTAMINANT

ND - NOT DETECTED

*** - EXCEEDS NEW YORK STATE/USEPA LIMITS FOR POTABLE WATER

WELL NO. 5-4 OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421 ⁽²³⁾		WELL NO. 5-3 N-8054 ⁽³⁾		WELL NO. 5-4 N-8595		WELL NO. 7-1 ⁽²⁷⁾	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)
<u>VOLATILE ORGANICS (CONT'D.)</u>										
1,3-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
CHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,1,1,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
BROMOBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,1,2,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,2,3-TRICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
2-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
4-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,2-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,3-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,4-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,2,4-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
HEXACHLOROBUTADIENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,2,3-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
BENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
TOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
ETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
M,P-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
O-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
STYRENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
ISOPROPYLBENZENE (CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
N-PROPYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
1,3,5-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 5-4 OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

**PLAINVIEW WATER DISTRICT
2008 WATER QUALITY DATA (continued)**

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 5-2 N-7421 ⁽²³⁾		WELL NO. 5-3 N-8054 ⁽³⁾		WELL NO. 5-4 N-8595		WELL NO. 7-1 ⁽²⁷⁾	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)
<u>VOLATILE ORGANICS (CONT'D.)</u>										
TERT-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
1,2,4-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
SEC-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
4-ISOPROPYLTOLUENE (P-CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
N-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND
METHYL TERT.BUTYL ETHER (MTBE)	10.0 ug/l	0.5 ug/l	ND	ND	ND	ND			ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 5-4 OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR